



**List of Approved Electronic Devices to be used on Eskom
Power Stations Standard, Appendix**

Related document	240-56227589	Rev	N/A
Effective Date	March 2023		
Compiler	J Strydom		
Eskom Generation			

APPENDIX 17: VOLTAGE MONITORING RELAYS FOR 380V AC

TYPE	MANUFACTURER	PASS / FAIL	Y2K Compliant	COMMENTS
ESN	Entrelec	Pass	N/A	
SX125/380A	Rhomberg Electronic	Fail	N/A	2kV Test failed
PFN	Entrelec	Pass	N/A	Fixed Settings
PVN	Entrelec	Pass	N/A	
PW380V-04X	Tele	Pass	N/A	Re-tested 20/2/97
CM-PVS	ABB	Pass	N/A	Over/Under Voltage
RXEDA 1	ABB	Pass	N/A	Time-over voltage only. AC or DC. No auxiliary supply.
3UG4615-1 CR20	Siemens	Pass	N/A	Up to 690V. Protection: phase sequence, phase loss, O/V, U/V, digital display, fault indications.
VME420	Bender	Pass	N/A	AC/DC over voltage, under voltage, over frequency and under frequency.
Vecto II	CT Lab	Pass	N/A	Power Quality Recorder with Osprey Light s/w 2.6.0 Build 46
Vecto III	CT Lab	Pass	N/A	Power Quality Recorder with Osprey Light s/w 2.6.0 Build 46

Disclosure classification: *(Controlled Disclosure)*

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30.