



**CONTRACTOR APPOINTMENT FOR MAINTENANCE OF ROOF VENTILATORS
AND HVAC MECHANICAL SYSTEMS AT O. R. TAMBO INTERNATIONAL
AIRPORT FOR A PERIOD OF 6 MONTHS.**

Tender Reference Number: RFQ 74932

18 September 2026

Issued by
Airports Company South Africa
O. R. Tambo International Airport

Note:

Upon Acceptance of the Offer by the Employer, this Tender Document becomes the Contract Document, subsequent to which, all references to the term “Tenderer(s)” then become synonymous with the term “Contractor”.

VOLUME 1

NAME OF TENDERER:

TENDERER'S DETAILS

1.	NAME OF TENDERER (BIDDING ENTITY)	(FULL NAME, i.e. (CC, (Pty) Ltd, JV, SOLE PROPRIETOR
.2.	TEL NUMBER	
.3.	FAX NUMBER	
.4.	EMAIL	
5.	NAME OF CONTACT	
6.	NATIONAL TREASURY CSD REGISTRATION NUMBER	

Contents	
The Contract	
Part C1: Agreement and Contract Data	
C1.1	Form of Offer and Acceptance
C1.2	Contract Data
C1.3	Occupational Health and Safety Agreement
C1.4	Forms of Securities
C1.5	Insurance Schedule
Part C2: Pricing data	
C2.1	Pricing Assumptions
C2.2	Price List
Part C3: Service Information	
Part C4: Site information	

Functionality / Technical Evaluation

The evaluation process will be based on threshold criteria and will be as follows:

	Description of quality criteria	WQ	Sub criteria	Score
			Quality Score	
1	Tenderer's resource proposal	70	Qualifications	40
			Years of experience in similar works	30
2	Company's References and experience	30	Company references of maintenance or project work	30
Total				100

Points allocated for Functionality shall be evaluated in accordance with the criteria listed above. An overall threshold of 75 points out of 100 must be achieved for the tender to pass functionality.

C1.1 Forms of Offer and Acceptance

Offer

The employer, identified in the acceptance signature block, wishes to enter into a contract for the

MAINTENANCE OF ROOF VENTILATORS AND HVAC MECHANICAL SYSTEMS FOR A PERIOD OF 6 MONTHS

The Contractor, identified in the offer signature block, has examined this document and addenda hereto as listed in the schedules, and by submitting this offer has accepted the conditions thereof.

By the representative of the Contractor, deemed to be duly authorised, signing this part of this form of offer and acceptance, the Contractor offers to perform all the obligations and liabilities of the Contractor under the contract including compliance with all its terms and conditions according to their true intent and meaning for an amount to be determined in accordance with the Conditions of Contract identified in the Contract Data.

The offered total of the Prices exclusive of VAT is	
Value Added Tax @ 15% is	
The total offered amount due inclusive of VAT is	
(in words)	

(The above amount should be calculated as per the guide provided in the Pricing Data [Subtotal F]. In the event of any conflict between the amount above and the Pricing Data [Subtotal F], the former shall prevail.)

for the Contractor

Signature Date

Name Capacity

(Name and address of organisation)

Name and signature
 of witness signature

This offer may be accepted by the employer by signing the acceptance part of this form of offer and acceptance and returning one copy of this document to the Bidder before the end of the period of validity stated in the tender data, whereupon the Bidder becomes the party named as the Contractor in the conditions of contract identified in the contract data.



Acceptance

By signing this part of this form of offer and acceptance, the employer identified below accepts the Contractor's offer. In consideration thereof, the employer shall pay the Contractor the amount due in accordance with the conditions of contract identified in the contract data. Acceptance of the Contractor's offer shall form an agreement between the employer and the Contractor upon the terms and conditions contained in this agreement and in the contract that is the subject of this agreement.

The terms of the contract, are contained in:

- Part C1: Agreements and contract data, (which includes this agreement)
 - Part C2: Pricing data and Price List
 - Part C3: Service information.
 - Part C4: Site information
- and schedules, drawings and documents or parts thereof where so indicated.

Deviations from and amendments to the documents listed in the tender data and any addenda thereto as listed in the tender schedules as well as any changes to the terms of the offer agreed by the Bidder and the employer during this process of offer and acceptance, are contained in the schedule of deviations attached to and forming part of this agreement. No amendments to or deviations from said documents are valid unless contained in this schedule.

The Contractor shall within two weeks after receiving a completed copy of this agreement, including the schedule of deviations (if any), contact the employer's agent (whose details are given in the contract data) to arrange the delivery of any bonds, guarantees, proof of insurance and any other documentation to be provided in terms of the conditions of contract identified in the contract data. Failure to fulfil any of these obligations in accordance with those terms shall constitute a repudiation of this agreement.

Notwithstanding anything contained herein, this agreement comes into effect on the date when the Bidder receives one fully completed original copy of this document, including the schedule of deviations (if any). Unless the Bidder (now Contractor) within five working days of the date of such receipt notifies the employer in writing of any reason why he cannot accept the contents of this agreement, this agreement shall constitute a binding contract between the parties.

for the Employer

Signature Date

Name Capacity

**Airports Company South Africa,
3rd Floor ACSA North Wing Offices
O R Tambo International Airport
Kempton Park
1627**

Name of
witness signature



Schedule of Deviations

1 Subject	
Details	
.....	
.....	
.....	
2 Subject	
Details	
.....	
.....	
.....	
3 Subject	
Details	
.....	
.....	
.....	
4 Subject	
Details	
.....	
.....	
.....	
5 Subject	
Details	
.....	
.....	

By the duly authorised representatives signing this agreement, the employer and the Contractor agree to and accept the foregoing schedule of deviations as the only deviations from and amendments to the documents listed in the tender data and addenda thereto as listed in the tender schedules, as well as any confirmation, clarification or changes to the terms of the offer agreed by the Bidder and the employer during this process of offer and acceptance.

It is expressly agreed that no other matter whether in writing, oral communication or implied during the period between the issue of the tender documents and the receipt by the Bidder of a completed signed copy of this Agreement shall have any meaning or effect in the contract between the parties arising from this agreement.

C1.2 Contract Data

Precedence in interpretation of the contract:

In the event of any ambiguity, inconsistency or conflict between the General Conditions of Contract, Special Conditions, Pricing Data, Service information, or other, the order of precedence shall be as follows:

Firstly, the Contract Data (C1.2) and Conditions of Contract;

Secondly the Pricing data;

Thirdly, the Service information (C3) and Annexes thereto shall prevail;

Fourthly, the additional conditions of contract under these Z clauses

Lastly any schedules, drawings and other documents included with this agreement.

General Conditions of Contract

The General Conditions of Contract comprise the NEC3 Term Service Contract, April 2013, published by the NEC, and the following "Particular Conditions", which include amendments and additions to such General Conditions.

The following Particular Conditions amplify the General Conditions of Contract and highlight areas in that document that require specific attention.

Wherein in the contract it is stated no contract data is required accordingly the *conditions of contract* remain unaltered as per NEC3 Term Service Contract, April 2013.

C1.2a - Data provided by the *Employer*

Clause	Statement	Data
1	General	
	The <i>conditions of contract</i> are the core clauses and the clauses for main Option:	
	dispute resolution Option:	A: Priced contract with price list W1: Dispute resolution procedure X1: Price Adjustment for inflation
	and secondary Options:	X2: Changes in the law X17: Low service damages X18: Limitation of Liability (as amended in Option Z) X19: Task Order X20: Key performance indicators Z: Additional conditions of contract
	of the NEC3 Term Service Contract (April 2013)	
10.1	The <i>Employer</i> is:	Airports Company South Africa SOC Limited (ACSA), Registration No 1993/004149/30, VAT no 4930138393, a juristic person incorporated in terms of the company laws of the Republic of South Africa
	Address	O. R. Tambo International Airport Private Bag X1 3rd Floor ACSA North Wing Offices OR Tambo International Airport 1627
	Tel No.	011 921 6911
10.1	The <i>Service Manager</i> is:	TBA
	Address	
	Tel No.	
	e-mail	
11.2(2)	The <i>Affected Property</i> is	O. R. Tambo International Airport

11.2(13)	The <i>service</i> is	Maintenance of Roof Ventilators And HVAC Mechanical Systems at O.R. Tambo International Airport for a period of 6 months, as more fully set out in section C3 <i>Service Information</i>.
11.2(14)	The following matters will be included in the Risk Register	1. Risk of financial loss and/or injury of 3rd parties due to the proximity of the <i>service</i> (or of persons providing the <i>service</i>) to all airport users 2. Risk of injury to contract personnel and all airport users due to lifting/moving of heavy objects 3. Work in confined spaces 4. Work with flammable and toxic gases 5 Refer to Annexure E for more risks
11.2(15)	The <i>Service Information</i> is in	Part C3: Employer's Service Information and all documents and drawings and other specifications to which it makes reference
12.2	The <i>law of the contract</i> is the law of	the Republic of South Africa
13.1	The <i>language of this contract</i> is	English
13.3	The <i>period for reply</i> is	3 working days
2	The Contractor's main responsibilities	Detailed in Part C3 (Service Information)
21.1	The <i>Contractor</i> submits a first plan for acceptance within	8 weeks of the Contract Date
3	Time	
30.1	The <i>starting date</i> is	Upon signing of the contract by ACSA
30.2	The <i>Service Period</i> is	Six (6) Months after signing of the contract by ACSA or when the amount in the Form of Offer has been expended, whichever occurs first
4	Testing and Defects	No data is required for this section of the <i>conditions of contract</i>
5	Payment	
50.1	The <i>assessment interval</i> is on the	between the 1st and 15th day of each successive month.
51.1	The <i>currency of this contract</i> is the	South African Rand (ZAR)
51.2	The period within which payments are made is	Thirty (30) days after receipt of a valid tax invoice

51.4	The <i>interest rate</i> is	The prime lending rate of the Nedbank Bank, as determined from time to time.
6	Compensation events	No data is required for this section of the <i>conditions of contract</i> .
7	Use of Equipment Plant and Materials	No data is required for this section of the <i>conditions of contract</i> .
8	Risks and insurance	
83.1	The <i>Employer</i> provides these insurances from the Insurance Table	(i) Insurance against loss of or damage to the <i>services</i>, Plant and Materials comprising Contract Works Insurance, SASRIA Special Risks Insurance and Marine & Air Cargo insurance; and (ii) Insurance (Public Liability Insurance) against liability for loss or damage to property (except the <i>services</i>, Plant and Materials and Equipment) and liability for bodily injury to or death of a person (not an employee of the <i>Contractor</i>) caused by activity in connection with the contract; Note: The terms and other matters applicable to these insurances provided by the Employer (and to insurances generally) are detailed in the insurance schedule attached as section C1.5 to the <i>contract</i> ("the Insurance Schedule").
83.1	The <i>Contractor</i> provides these additional insurances	Professional Indemnity Insurance Note: The terms and other matters applicable to this insurance provided by the Employer are likewise detailed in section C1.5 to the <i>contract</i>.
83.2	The minimum amounts of cover or minimum limits of indemnity required for the insurance table	Refer to section C1.5 Insurance Schedule
83.1	The <i>Employer</i> provides these insurances from the Insurance Table	Refer to section C1.5 Insurance Schedule
83.1	The <i>Employer</i> provides these additional insurances	Refer to section C1.5 Insurance Schedule
83.1	The minimum amount of cover for insurance against loss and damage caused by the <i>Contractor</i> to the <i>Employer's</i> property is	Refer to section C1.5 Insurance Schedule
83.1	The minimum amount of cover for loss of or damage to Plant and Materials provided by the <i>Employer</i> is:	Refer to section C1.5 Insurance Schedule

83.1	The minimum amount of cover for insurance in respect of loss of or damage to property (except the <i>Employer's</i> property, Plant and Materials and Equipment) and liability for bodily injury to or death of a person (not an employee of the <i>Contractor</i>) arising from or in connection with the <i>Contractor's</i> Providing the Service for any one event is:	Refer to section C1.5 Insurance Schedule
83.1	The minimum limit of indemnity for insurance in respect of death of or bodily injury to employees of the <i>Contractor</i> arising out of and in the course of their employment in connection with this contract for any one event is:	As prescribed by the Compensation for Occupational Injuries and Diseases Act No. 130 of 1993 and the <i>Contractor's</i> common law liability for people falling outside the scope of the Act with a limit of Indemnity of not less than R [•] ([•] Rands)
9	Termination	There is no reference to Contract Data in this section of the core clauses and terms in italics used in this section are identified elsewhere in this Contract Data.
10	Data for main Option clause	
A	Priced contract with price list	
20.5	The <i>Contractor</i> prepares forecasts of the final total of the Prices for the whole of the <i>service</i> at intervals no longer than	4 weeks.
11	Data for Option W1	
W1.1	The <i>Adjudicator</i> is	The person selected from the ICE-SA list of Adjudicators by the Party intending to refer a dispute to him [ICE-SA is a joint Division of the South African Institution of Civil Engineering and the Institution of Civil Engineers (London) (see www.ice-sa.org.za) or its successor body]
W1.2(3)	The <i>Adjudicator nominating body</i> is:	The Chairman of ICE-SA a joint Division of the South African Institution of Civil Engineering and the Institution of Civil Engineers (London) (see www.ice-sa.org.za) or its successor body
W1.4(2)	The <i>tribunal</i> is:	arbitration
W1.4(5)	The <i>arbitration procedure</i> is	The latest edition of Rules for the Conduct of Arbitrations published by The Association of Arbitrators (Southern Africa) or its successor body
	The place where arbitration is to be held is	Johannesburg, South Africa

The person or organization who will choose an arbitrator

The Chairman for the time being or his nominee of the Association of Arbitrators (Southern Africa) or its successor body

12	Data for secondary Option	
X1	Price Adjustment for inflation	The index referred to in this clause shall be deemed to refer to the CPI index on the <i>starting date</i>. Price adjustment for inflation shall only take place on contract anniversary
X2	Changes in the law	No data is required for this secondary Option
X13	Performance bond	
X13.1	The amount of the performance bond is	Refer to section C1.4 Forms of Sureties
X17	Low service damages	As per the Service Information (C3) – Annex I section 6
X17.1	The <i>service level table</i> is in	The Service Information, Annex I
X18	Limitation of liability	
X18.1	The <i>Contractor's</i> liability to the <i>Employer</i> for indirect or consequential loss is limited to	Nil - Neither Party is liable to the other for any consequential or indirect loss, including but not limited to loss of profit, loss of income or loss of revenue
X18.2	For any one event, the <i>Contractor's</i> liability to the <i>Employer</i> for loss of or damage to the <i>Employer's</i> property is limited to	The Total liability incurred and/or damages suffered to the employer's property
X18.3	The <i>Contractor's</i> liability for Defects due to his design of an item of Equipment is limited to	The Total liability incurred and/or damages suffered to the employer's property
X18.4	The <i>Contractor's</i> total liability to the <i>Employer</i> , for all matters arising under or in connection with this contract, other than the excluded matters, is limited to	The Contractor's total direct liability to the Employer for all matters arising under or in connection with this contract, other than the excluded matters, is limited to the Total liability incurred and/or damages suffered to the employer's property and applies in contract, tort or delict and otherwise to the extent allowed under the law of the contract. The excluded matters are amounts payable by the Contractor as stated in this contract for: - Loss of or damage to the Employer's property, - Defects liability, - Insurance liability to the extent of the Contractor's risks - death of or injury to a person;

		infringement of an intellectual property right
X18.5	The <i>end of liability date</i> is	52 weeks after the end of the service period.
X19	Task Order	
X19.5	The <i>Contractor</i> submits a Task Order programme to the <i>Service Manager</i> within	5 days of receiving the Task Order
X20	Key Performance Indicators	
X20.2	A report of performance against each Key Performance Indicator is provided at intervals of	Three (3) months

Z	The <i>additional conditions of contract</i> are
AMENDMENTS TO THE CORE CLAUSES	
Z1	Interpretation of the law
Z1.1	Add to core clause 12.3: Any extension, concession, waiver, non-enforcement of any terms of the contract or relaxation of any action stated in this contract by the Parties, the <i>Service Manager</i> , the, or the <i>Adjudicator</i> does not constitute a waiver of rights, and does not give rise to an estoppel unless the Parties agree otherwise and confirm such agreement in writing.
Z2	Providing the Service: Delete core clause 20.1 and replace with the following:
Z2.1	The <i>Contractor</i> provides the <i>service</i> in accordance with the <i>Service</i> Information and warrants that the results of the <i>service</i> , when complete, shall be fit for their intended purpose.
Z3.	Other responsibilities: add the following at the end of core clause 27:
Z3.1	The <i>Contractor</i> shall have satisfied himself, prior to the <i>starting date</i> , as to the completeness, sufficiency and accuracy of all information and drawings provided to him as at the <i>starting date</i> .
Z3.2	The <i>Contractor</i> shall be responsible for the correct setting out or carrying out of the <i>service</i> in accordance with the original points, lines and levels stated in the <i>Service</i> Information or notified by the <i>Service Manager</i> ,. Any errors in the setting or carrying out of the <i>service</i> shall be rectified by the <i>Contractor</i> at the <i>Contractor's</i> own costs.
Z4.	Termination
Z4.1	Add the following to core clause 91.1, at the second main bullet, fourth sub-bullet point, after the words “assets or”: “business rescue proceedings are initiated or steps are taken to initiate business rescue proceedings”.
Z4.2	Add the following to core clause 91.8, The <i>Employer</i> may terminate the Contract in the event that the <i>Contractor</i> is unable to maintain an average availability of 91% for a continuous period of twenty-four (24) weeks as measured by ACSA IMCS system (R22).
Z4.3	Add the following to the Termination Table: If the Employer terminates in terms of this clause 91.8, the procedures on termination are P1, P3 and P4 as stated in clause 92, and the amount due is A1 and A2 as stated in clause 93.
Z5	Ambiguities and inconsistencies: Delete core clause 17 and replace with the following:
Z5.1	If there is any ambiguity or inconsistency in or between the documents which are part of this contract, the priority of the documents is in accordance with the following sequence: • Firstly, the Contract Data (C1.2) and Conditions of Contract; • Secondly the Pricing data; • Thirdly, the Service information (C3) and Annexes thereto shall prevail; • Fourthly, the additional conditions of contract under these Z clauses • Lastly any schedules, drawings and other documents included with this agreement.

Z5.2 The *Service Manager* or the *Contractor* notifies the other as soon as either becomes aware of any such ambiguity or inconsistency in or between the documents which are part of this contract. The *Service Manager* gives an instruction resolving the ambiguity or inconsistency. Notwithstanding any other provision of this contract, any such ambiguity, inconsistency and/or instruction does not automatically result in any increase to the *price list* or any delay to the end of the *service period*.

Z6 **Payment: Add the following at the end of core clause 51:**

51.5 The *Employer* does not pay interest to the *Contractor* on a late payment resulting from the *Contractor's* failure to provide the *Employer* with a correctly rendered VAT invoice within the period stated in clause 51.1 above.

51.5 The *Employer* is entitled to deduct from or set off against any money due to the *Contractor*

- any sum due to the *Employer* from the *Contractor* or
- any amount for which the *Contractor* is liable to pay to the *Employer* (whether liquidated or otherwise) arising under this contract.

AMENDMENTS TO THE SECONDARY OPTION CLAUSES

Z7. **Changes in Law: Add the following clause to secondary option X2 as X2.2:**

Z7.1 A change in law is defined as:

Z7.1.1 the adoption, enactment, promulgation, coming into effect, repeal, amendment, reinterpretation, change in application or other modification after the starting date of any law, excluding (i) the promulgation of any bill, unless such bill is enacted into the *law of the country*, and (ii) any such modification in law relating to any taxes, charges, imposts, duties, levies or deductions that are assessed in relation to a person's income;

Z7.1.2 any permit being terminated, withdrawn, amended, modified or replaced, other than (i) in accordance with the terms upon which it was originally granted, (ii) as a result of the failure by the *Contractor* to comply with any condition set out therein, or (iii) as a result of any act or omission of the *Contractor*, any subcontractor or any affiliate to the *Contractor*.

Z8. **Performance Bond: The following amendments are made to clause X13:**

Z8.1 **Amend the first sentence of clause X13.1 to read as follows:** The *Contractor* gives the *Employer* an unconditional, on-demand performance bond, provided by a bank or insurer which the *Service Manager* has accepted in his or her discretion, for the amount stated in the Contract Data and in the form set out in Section C1.4 of this Contract Data.

Z8.2 **Add the following new clause as Option X13.2:** The *Contractor ensures* that the performance bond is valid and enforceable until the end of the *service period*. If the terms of the performance bond specify its expiry date and the end of the *service period* does not coincide with such expiry date, four weeks prior to the said expiry date, the *Contractor* extends the validity of the performance bond until the end of the *service period*. If the *Contractor* fails to so extend the validity of the performance bond, the *Employer* may claim the full amount of the performance bond and retain the proceeds as cash security.

Z9 **Limitation of liability: Insert the following new clause as Option X18.6:**

Z9.1 The *Employer's* liability to the *Contractor* for the *Contractor's* indirect or consequential loss or damage of any kind is limited to R0.00.

- Z9.2** Notwithstanding any other clause in this contract, any proceeds received from any insurance or any proceeds which would have been received from any insurances but for the conduct of the *Contractor* shall be excluded from the calculation of the limitations of liability listed in the contract.

ADDITIONAL Z CLAUSES

Z10 Cession, delegation and assignment

- Z10.1** The *Contractor* shall not cede, delegate or assign any of its rights or obligations to any person without the written consent of the *Employer*, which consent shall not be unreasonably withheld. This clause shall be binding on the liquidator/business rescue practitioner /trustee (whether provisional or final) of the *Contractor*.

- Z10.2** The *Employer* may, on written notice to the *Contractor*, cede and delegate its rights and obligations under this contract to any person or entity.

Z11 Joint and several liability

- Z11.1** If the *Contractor* constitutes a joint venture, consortium or other unincorporated grouping of two or more persons, these persons are deemed to be jointly and severally liable to the *Employer* for the performance of this Contract.

- Z11.2** The *Contractor* shall, within 1 week of the starting date, notify the *Service Manager* and the *Employer* of the key person who has the authority to bind the *Contractor* on its behalf.

- Z11.3** The *Contractor* does not materially alter the composition of the joint venture, consortium or other unincorporated grouping of two or more persons without prior written consent of the *Employer*.

Z12. Ethics

- Z12.1** The *Contractor* undertakes:

- Z12.1.2** not to give any offer, payment, consideration, or benefit of any kind, which constitutes or could be construed as an illegal or corrupt practice, either directly or indirectly, as an inducement or reward for the award or in execution of this contract;

- Z12.1.2** to comply with all laws, regulations or policies relating to the prevention and combating of bribery, corruption and money laundering to which it or the *Employer* is subject, including but not limited to the Prevention and Combating of Corrupt Activities Act, 12 of 2004.

- Z12.2** The *Contractor's* breach of this clause constitutes grounds for terminating the *Contractor's* obligation to Provide the Service in accordance with the procedures stated P2, P3 or P4 in core clause 92.2 or taking any other action as appropriate against the *Contractor* (including civil or criminal action). However, lawful inducements and rewards shall not constitute grounds for termination.

- Z12.3** If the *Contractor* is found guilty by a competent court, administrative or regulatory body of participating in illegal or corrupt practices, including but not limited to the making of offers (directly or indirectly), payments, gifts, gratuities, commission or benefits of any kind, which are in any way whatsoever in connection with the contract with the *Employer*, the *Employer* shall be entitled to terminate the contract in accordance with the procedures stated in core clause 92.2, the amount due on termination is A1.

Z13 Confidentiality

- Z13.1** All information obtained in terms of this contract or arising from the implementation of this contract shall be treated as confidential by the *Contractor* and shall not be used or divulged or

published to any person not being a party to this contract, without the prior written consent of the *Service Manager*, whose consent shall not be unreasonably withheld.

- Z13.2** If the *Contractor* is uncertain about whether any such information is confidential, it is to be regarded as such until otherwise notified by the *Service Manager*.
- Z13.3** This undertaking shall not apply to –
- Z13.3.1** information disclosed to the employees of the *Contractor* for the purposes of the implementation of this contract. The *Contractor* undertakes to ensure that its employees are aware of the confidential nature of the information so disclosed and that they comply with the provisions of this clause;
- Z13.3.2** information which the *Contractor* is required by law to disclose, provided that the *Contractor* notifies the *Employer* prior to disclosure so as to enable the *Employer* to take the appropriate action to protect such information. The *Contractor* may disclose such information only to the extent required by law and shall use reasonable efforts to obtain assurances that confidential treatment will be afforded to the information so disclosed;
- Z13.3.3** information which at the time of disclosure or thereafter, without default on the part of the *Contractor*, enters the public domain or to information which was already in the possession of the *Contractor* at the time of disclosure (evidenced by written records in existence at that time);
- Z13.4** The taking of images (whether photographs, video footage or otherwise) of the *services* or *Affected Property* or any portion thereof, in the course of providing the *services* or at the end of the service period requires the prior written consent of the *Service Manager*. All rights in and to all such images vests exclusively in the *Employer*.
- Z13.5** The *Contractor* ensures that all his Subcontractors abide by the undertakings in this clause.
- Z14** ***Employer's Step-in rights***
- Z14.1** If the *Contractor* defaults by failing to comply with its obligations in terms of this contract and fails to remedy such default within two (2) weeks of the notification of the default by the *Service Manager*, the *Employer*, without prejudice to its other rights, powers and remedies under the contract, or at law may remedy the default either, itself or procure a third party (including any subcontractor or supplier of the *Contractor*) to do so on its behalf. The reasonable costs of the *Employer* exercising its step-in rights in respect of any subcontractor or supplier of the *Contractor* shall be borne by the *Contractor*.
- Z14.2** The *Contractor* co-operates with the *Employer* and facilitates and permits the use of all required information, materials and other matter (including but not limited to documents and all other drawings, CAD materials, data, software, models, plans, designs, programs, diagrams evaluations, materials, specifications, schedules, reports, calculations, manuals or other documents or recorded information (electronic or otherwise) which have been or are at any time prepared by or on behalf of the *Contractor* under the contract or otherwise for and/or in connection with the *works*) and generally does all things required by the *Service Manager* to achieve this end
- Z15** ***Liens and Encumbrances***
- Z15.1** The *Contractor* keeps the Equipment used to Provide the Service free of all liens and other encumbrances at all times. The *Contractor*, vis-a-vis the *Employer*, waives all and any liens which he may from time to time have, or become entitled to over such Equipment and any part thereof and ensures that his Subcontractors similarly, vis-a-vis the *Employer*, waive all liens they may have or become entitled to over such Equipment from time to time
- Z16** ***Intellectual Property***

- Z16.1** Intellectual Property (“IP”) rights means all rights in and to any patent, design, copyright, trade mark, trade name, trade secret, other intellectual or industrial property rights, technical information and concepts, know-how, specifications, data, formulae, computer programs, memoranda, scripts, reports, manuals, diagrams, drawings, prototypes, drafts and any rights to them created during the performance of the service and include applications for and rights to obtain or use any such intellectual property whether under South African or foreign law.
- Z16.2** IP rights remain vested in the originator and shall not be used for any reason whatsoever other than carrying out the *service*.
- Z16.3** The *Contractor* gives the *Employer* an irrevocable, transferrable, non-exclusive, royalty free licence to use and copy all IP related to the *service* for the purposes of constructing, repairing, demolishing, operating and maintaining the *service* or *the Affected Property*.
- Z16.4** The written approval of the *Contractor* is to be obtained before the *Contractor's* IP made available to any third party which approval will not be unreasonably withheld or delayed. Prior to making any *Contractor's* IP available to any third party the *Employer* shall obtain a written confidentiality undertaking from any such third party on terms no less onerous than the terms the *Employer* would use to protect its IP.
- Z16.5** The *Contractor* shall indemnify and hold the *Employer* harmless against and from any claim alleging an infringement of IP rights (“**the claim**”), which arises out of or in relation to:
- Z16.5.1** the *Contractor's service*;
- Z16.5.2** the use of the *Contractor's* Equipment, or
- Z16.5.3** the proper use of the *Affected Property* on which the service is provided.
- Z16.6** The *Employer* shall, at the request and cost of the *Contractor*, assist in contesting the claim and the *Contractor* may (at its cost) conduct negotiations for the settlement of the claim, and any litigation or arbitration which may arise from it.
- Z17. Dispute resolution: The following amendments are made to Option W1:**
- Z17.1** Under clause W1.3, in the fourth row of the first column of the adjudication table, the following words are added after the words “any other matter”: “excluding disputes relating to termination of the contract”.
- Z17.2** The following clauses are added at the end of clause W1.3 as sub-clauses (12) and (13) respectively:
- Z17.2.1** “The Adjudicator shall decide the dispute solely on the written submissions of the parties. No oral submissions shall be heard during adjudication.”
- Z17.2.2** “Disputes relating to or arising from termination of the Contract shall not be determined by an adjudicator. Any such dispute shall be referred directly to the tribunal in accordance with the procedures set out in clause W1.4.”
- Z18 Day:**
- Z18.1** Any reference to a day in terms of this contract shall be construed as a calendar day.
- Z19 Safety:**



- Z19.1** The *Employer*, *Service Manager* or any of his nominated representatives may stop any unsafe *service*. The *Contractor* does not proceed with the relevant service until the safety violation is corrected. This instruction to stop or not to start the *service* is not a compensation event.
- Z19.2** As stipulated by section 37(2) of the Occupational Health and Safety Act No. 85 of 1993 (**OHS Act**) as amended the Contractor agrees to the following:
- Z19.2.1** As part of the contract, the *Contractor* acknowledges that it is an *Employer* in its own right with duties as prescribed in the OHS Act, as amended and agrees to ensure that all work performed, or equipment and materials used, are in accordance with the provisions of the OHS Act.
- Z19.2.2** The *Contractor* furthermore agrees to comply with the requirements set forth by the *Service Manager* and agree to liaise with the *Employer* should the *Contractor*, for whatever reason, be unable to perform in terms of the clause Z18.
- Z19.3** The *Contractor* acknowledges that it is an *Employer* in its own right and is registered with duties as prescribed in the Compensation for Occupational Injuries & Diseases Act No. 130 of 1993.

C1.2 b - DATA PROVIDED BY THE CONTRACTOR

Clause	Statement	Data
10.1	The Contractor is (Name):	
	Company Registration Number	
	Company VAT Number	
	Address	
	Telephone no.	
	Fax No.	
11.2	The <i>working areas</i> are	See C3 'Service Information'
11.2(8)	The direct fee percentage is:	10%
	The subcontracted fee percentage is:	10%
24.1	The <i>Contractor's Key people</i> are:	CV's to be appended to Resource Proposal (Annex F)
1	SITE MANAGER/SUPERVISOR	
	Name:	
	Qualifications relevant to this contract	
	Experience	
2	Control Technician	

Name:

Qualifications relevant to this contract

Experience

3 Refrigeration Mechanic

Name:

Qualifications relevant to this contract

Experience

4 Assistant

Name:

Qualifications relevant to this contract

Experience

11.2 The following matters will be 1.
included in the Risk Register

2.

3.

4.

5.

6.

C1.3 Occupational Health and Safety Agreement

OCCUPATIONAL HEALTH AND SAFETY AGREEMENT

AGREEMENT IN TERMS OF SECTION 37(2) OF THE OCCUPATIONAL HEALTH & SAFETY ACT (ACT 85 OF 1993) & CONSTRUCTION REGULATION 5.1(k)

OBJECTIVES

To assist Airport Company South Africa (ACSA) in order to comply with the requirements of:

1. The Occupational Health & Safety (Act 85 of 1993) and its regulations and
2. The Compensation for Occupational Injuries & Diseases Act (Act 130 of 1993) also known as the (COID Act).

To this end an Agreement must be concluded before any contractor/ subcontracted work may commence

The parties to this Agreement are:

Name of Organization: AIRPORTS COMPANY SOUTH AFRICA O R Tambo INTERNATIONAL AIRPORT
Physical Address: Airport Company South Africa OR Tambo International Airport ACSA Building, 4th Floor

Hereinafter referred to as “Client”

Name of organisation:
Physical Address:

Hereinafter referred to as “the Mandatary/ Principal Contractor”

MANDATORY'S MAIN SCOPE OF WORK

GENERAL INFORMATION FORMING PART OF THIS AGREEMENT

1. The Occupational Health & Safety Act comprises of SECTION 1-50 and all unrepealed REGULATIONS promulgated in terms of the former Machinery and Occupational Safety Act No.6 of 1983 as amended as well as other REGULATIONS which may be promulgated in terms of the Act and other relevant Acts pertaining to the job in hand.
2. "Mandatory" is defined as including as agent, a principal contractor or a contractor for work, but WITHOUT DEROGATING FROM HIS/HER STATUS IN HIS/HER RIGHT AS AN EMPLOYER or user of the plant
3. Section 37 of the Occupational Health & Safety Act potentially punishes Employers (PRINCIPAL CONTRACTOR) for unlawful acts or omissions of Mandatories (CONTRACTORS) save where a Written Agreement between the parties has been concluded containing arrangements and procedures to ensure compliance with the said Act BY THE MANDATARY.
4. All documents attached or refer to in the above Agreement form an integral part of the Agreement.
5. To perform in terms of this agreement Mandatories must be familiar and conversant with the relevant provisions of the Occupational Health & Safety Act 85 of 1993 (OHS Act) and applicable Regulations.
6. Mandatories who utilise the services of their own Mandatories (contractors) must conclude a similar Written Agreement with them.
7. Be advised that this Agreement places the onus on the Mandatory to contact the CLIENT in the event of inability to perform as per this Agreement.
8. This Agreement shall be binding for all work the Mandatory undertakes for the client.
9. All documentation according to the Safety checklist including a copy of the written Construction Manager appointment in terms of construction regulation 8, must be submitted 7 days before work commences.

THE UNDERTAKING

The Mandatory undertakes to comply with:

INSURANCE

1. The Mandatory warrants that all their employees and/or their contractor's employees if any are

covered in terms of the COID Act, which shall remain in force whilst any such employees are present on the Client's premises. A letter is required prior commencing any work on site confirming that the Principal contractor or contractor is in good standing with the Compensation Fund or Licensed Insurer.

2. The Mandatary warrants that they are in possession of the following insurance cover, which cover shall remain in force whilst they and /or their employees are present on the Client's premises, or which shall remain in force for that duration of their contractual relationship with the Client, whichever period is the longest.
 - a. Public Liability Insurance Cover as required by the Subcontract Agreement.
 - b. Any other Insurance cover that will adequately makes provision for any possible losses and/or claims arising from their and /or their Subcontractors and/or their respective employee's acts and/or omissions on the Client's premises.

COMPLIANCE WITH THE OCCUPATIONAL HEALTH & SAFETY ACT 85 OF 1993
--

The Mandatary undertakes to ensure that they and/or their subcontractors if any and/or their respective employees will at all times comply with the following conditions:

1. All work performed by the Mandatary on the Client's premises must be performed under the close supervision of the Mandatary's employees who are to be trained to understand the hazards associated with any work that the Mandatary performs on the Client's premises.
2. The Mandatary shall be assigned the responsibility in terms of Section 16(1) of the OHS Act 85 of 1993, if the Mandatary assigns any duty in terms of Section 16(2), a copy of such written assignment shall immediately be forwarded to the Client.
3. The Mandatary shall ensure that he/she familiarise himself/herself with the requirements of the OHS Act 85 of 1993 and that s/he and his/her employees and any of his subcontractors comply with the requirements.
4. The Mandatary shall ensure that a baseline risk assessment is performed by a competent person before commencement of any work in the Client's premises. A baseline risk assessment document will include identification of hazards and risk, analysis and evaluation of the risks and hazards identified, a documented plan and safe work procedures to mitigate, reduce or control the risks identified, and a monitoring and review plan of the risks and hazards.
5. The Mandatary shall appoint competent persons who shall be trained on any Occupational Health & Safety aspect pertaining to them or to the work that is to be performed.
6. The Mandatary shall ensure that discipline regarding Occupational Health & Safety shall be strictly enforced.
7. Any personal protective equipment required shall be issued by the Mandatary to his/her

employees and shall be worn at all times.

8. Written safe working practices/procedures and precautionary measures shall be made available and enforced and all employees shall be made conversant with the contents of these practises.
9. No unsafe equipment/machinery and/or articles shall be used by the Mandatary or contractor on the Client's premises.
10. All incidents/accidents referred to in OHSAct shall be reported by the Mandatary to the Provincial Director: Department of Labour as well as to the Client.
11. No use shall be made by the Mandatary and/or their employees and or their subcontractors of any of the Client's machinery/article/substance/plant/personal protective equipment without prior written approval.
12. The Mandatary shall ensure that work for which the issuing of permit is required shall not be performed prior to the obtaining of a duly completed approved permit.
13. The Mandatary shall ensure that no alcohol or any other intoxicating substance shall be allowed on the Client's premises. Anyone suspected to be under the influence of alcohol or any other intoxicating substance shall not be allowed on the premises. Anyone found on the premises suspected to be under the influence of alcohol or any other intoxicating substance shall be escorted off the said premises immediately.
14. Full participation by the Mandatary shall be given to the employees of the Client if and when they inquire into Occupational Health & Safety.

FURTHER UNDERTAKING

1. Only a duly authorised representative appointed in terms of Section 16.2 of the OHS Act is eligible to sign this agreement on behalf of the Mandatary. The signing power of this representative must be designated in writing by the Chief Executive Officer of the Mandatary. A copy of this letter must be made available to the Client.
2. The Mandatary confirms that he has been informed that he must report to the Client's management, in writing anything he/she deems to be unhealthy and /or unsafe. He has versed his employees in this regard.
3. The Mandatary warrants that he/she shall not endanger the health & safety of the Client's employees and other persons in any way whilst performing work on the Client's premises.
4. The Mandatary understands that no work may commence on the Client's premises until this procedure is duly completed, signed and received by the Client.
5. Non-compliance with any of the above clauses may lead to an immediate cancellation of the contract.



ACCEPTANCE BY MANDATARY

In terms of section 37(2) of the Occupational Health & Safety Act 85 of 1993 and section 5.1(k) of the Construction Regulations 2014,

Ia duly authorised 16.2 Appointee acting for and on behalf of(company name) undertake to ensure that the requirements and the provision of the OHS Act 85 of 1993 and its regulations are complied with.

Mandatory – WCA/ Federated Employers Mutual No.....

Expiry date

SIGNATURE ON BEHALF OF MANDATARY
(Warrant his authority to sign)

DATE

SIGNATURE ON BEHALF OF THE CLIENT
AIRPORT COMPANY SOUTH AFRICA

DATE

C1.4 Forms of Securities

No performance bond or parent company guarantee is required in this contract

Pro forma Performance Bond – Demand Guarantee (for use with Option X13) (to be reproduced exactly as shown below on the letterhead of the Bank providing the Bond / Guarantee)

Airports Company South Africa SOC Limited
Reg. No 1993/004149/30 VAT no 4930138393
O R Tambo International Airport
Private Bag X1
3rd Floor ACSA North Wing Offices
OR Tambo International Airport
1627

Bank reference No.

Date:

Dear Sirs,

Performance Bond – Demand Guarantee for [insert name of Contractor] required in terms of contract [insert Contractor's contract reference number or title]

1. In this Guarantee the following words and expressions shall have the following meanings:-

1.1	"Bank" means	[Insert name of Bank], [●] Branch, Registration No. [●]
1.2	"Bank's Address" means	[Insert physical address of Bank]
1.3	"Contract" means	the written agreement relating to the Service, entered into between the Employer and the Contractor on or about the [●] day of [●] 20[●] (Contract Reference No. [●]) as amended, varied, restated, novated or substituted from time to time;
1.4	"Contractor" means	[●] a company registered in accordance with the laws of [●] under Registration No [●].
1.5	"Employer" means	Airports Company South Africa SOC Limited, a company registered in accordance with the laws of the Republic of South Africa under Registration Number 1993/004149/30
1.6	"Expiry Date" means	the earlier of - the date that the Bank receives a notice from the Employer stating that all amounts due from the Contractor as certified in terms of the contract have been received by the Employer and that the Contractor has fulfilled all his obligations under the Contract, or - the date that the Bank issues a replacement Bond for such lesser or higher amount as may be required by the Employer.
1.7	"Guaranteed Sum" means	the sum of R[●], ([●] Rand)
1.8	"Service" means	Maintenance of Roof Ventilators And HVAC Mechanical Systems set out in the Section C3, Works Information

2. At the instance of the Contractor, we the undersigned _____ and _____, in our respective capacities as _____ and _____ of the Bank, and duly authorized thereto,



confirm that we hold the Guaranteed Sum at the disposal of the Employer as security for the proper performance by the Contractor of all of its obligations in terms of and arising from the Contract and hereby undertake to pay to the Employer, on written demand from the Employer received prior to the Expiry Date, any sum or sums not exceeding in total the Guaranteed Sum.

3. A demand for payment under this guarantee shall be made in writing at the Bank's address and shall:
 - be signed on behalf of the Employer by a director of the Employer;
 - state the amount claimed ("the Demand Amount");
 - state that the Demand Amount is payable to the Employer in the circumstances contemplated in the Contract.
4. Notwithstanding the reference herein to the Contract the liability of the Bank in terms hereof is as principal and not as surety and the Bank's obligation/s to make payment:
 - is and shall be absolute provided demand is made in terms of this bond in all circumstances; and
 - is not, and shall not be construed to be, accessory or collateral on any basis whatsoever.
5. The Bank's obligations in terms of this Guarantee:
 - shall be restricted to the payment of money only and shall be limited to the maximum of the Guaranteed Sum; and
 - shall not be discharged and compliance with any demand for payment received by the Bank in terms hereof shall not be delayed, by the fact that a dispute may exist between the Employer and the Contractor.
6. The Employer shall be entitled to arrange its affairs with the Contractor in any manner which it sees fit, without advising us and without affecting our liability under this Guarantee. This includes, without limitation, any extensions, indulgences, release or compromise granted to the Contractor or any variation under or to the Contract.
7. Should the Employer cede its rights against the Contractor to a third party where such cession is permitted under the Contract, then the Employer shall be entitled to cede to such third party the rights of the Employer under this Guarantee on written notification to the Bank of such cession.
8. This Guarantee:
 - shall expire on the Expiry Date until which time it is irrevocable;
 - is, save as provided for in 7 above, personal to the Employer and is neither negotiable nor transferable;
 - shall be returned to the Bank upon the earlier of payment of the full Guaranteed Sum or expiry hereof;
 - shall be regarded as a liquid document for the purpose of obtaining a court order; and
 - shall be governed by and construed in accordance with the law of the Republic of South Africa and shall be subject to the jurisdiction of the Courts of the Republic of South Africa.
 - will be invalid and unenforceable if any claim which arises or demand for payment is received after the Expiry Date.
9. The Bank chooses domicilium citandi et executandi for all purposes in connection with this Guarantee at the Bank's Address.

Signed at _____ on this _____ day of _____ 20__

For and on behalf of the Bank

Bank Signatories(s)



Name(s) (printed)

Witness(s)

Bank's seal or stamp

C1.5 Insurance Schedule

Summary of Terms and other Matters Applicable to Employer Provided Insurance

The successful bidder must source the following insurance cover, which is the deductible in the ACSA insurance cover:

- *Aviation liability insurance cover for an indemnity limit not less than R300 000 (three hundred thousand rands).*
- *Submit proof of insurance to ACSA before the work starts, and annually for the duration of the project.*

C2.1 Pricing assumptions: Option A

The conditions of contract

How work is priced and assessed for payment

Clause 11 in NEC3 Term Service Contract, April 2013 (TSC3) core clauses and Option A states:

- | | | |
|-------------------------------------|------------|--|
| Identified and defined terms | 11
11.2 | (12) The Price List is the <i>price list</i> unless later changed in accordance with this contract.

(17) The Price for Services Provided to Date is the total of

the Price for each lump sum item in the Price List which the <i>Contractor</i> has completed and
where a quantity is stated for an item in the Price List, an amount calculated by multiplying the quantity which the <i>Contractor</i> has completed by the rate.

(19) The Prices are the amounts stated in the Price column of the Price List. Where a quantity is stated for an item in the Price List, the Price is calculated by multiplying the quantity by the rate. |
|-------------------------------------|------------|--|

This confirms that Option A is a priced contract where the Prices are derived from a list of items of service which can be priced as lump sums or as expected quantities of service multiplied by a rate or a mix of both. Where it is contemplated that the Price List represents the type of work, quantity and cost thereof which may or not be selected by the Employer, it is important to ensure that service items listed do not create liability on a daily basis if that is not the intention. For example, if the service is maintenance of an installation on an ad hoc or call-off basis which may require the Contractor to be on standby but not permanently on the Affected Property, avoid listing service items which may be treated as preliminary and general (P&Gs) items, whether fixed or time-related such as contractual requirements, establishing on site, offices, storage, ablutions, water supplies, power supply, telecommunications. The Price List should align with the intention of the contract and selection of Option X 19 should be considered. If the Contractor is required to price P&G items ensure that the tender, contract and Price List provides clearly that daily charges are applicable only as necessitated by the specific activity and authorised by the Service Manager. Particular care should be taken when utilising SANS 1200 as a guide for tenderers or for preparing templates for Price Lists in tenders. Avoid referring to the Price List as the Activity Schedule.

Function of the Price List

Clause 54.1 in Option A states: "Information in the Price List is not Service Information". This confirms that instructions to do work or how it is to be done are not included in the Price List but in the Service Information. This is further confirmed by Clause 20.1 which states, "The *Contractor* Provides the Service in accordance with the Service Information". Hence the *Contractor* does **not** Provide the Service in accordance with the Price List. The Price List is only a pricing document.

Link to the *Contractor's* plan

Clause 21.4 states "The *Contractor* provides information which shows how each item description on the Price List relates to the operations on each plan which he submits for acceptance". Hence when compiling the *price*

list, the tendering contractor needs to develop his first clause 21.2 plan in such a way that operations shown on it can be priced in the *price list* and result in a satisfactory cash flow in terms of clause 11.2(17).

Preparing the *price list*

It will be assumed that the tendering contractor has read Pages 14, 15 and 76 of the TSC3 Guidance Notes before preparing the *price list*. Items in the *price list* may have been inserted by the *Employer* and the tendering contractor should insert any additional items which he considers necessary. Whichever party provides the items in the *price list* the total of the Prices is assumed to be fully inclusive of everything necessary to Provide the Service as described at the time of entering into this contract.

1 As the *Contractor* has an obligation to correct Defects (core clause 42.1) and there is no compensation event for this unless the Defect was due to an *Employer's* risk, the lump sum Prices and rates must also include for the correction of Defects.

2 If the *Contractor* has decided not to identify a particular item in the *price list* at the time of tender the cost to the *Contractor* of doing the work must be included in, or spread across, the other Prices and rates in the *price list* in order to fulfil the obligation to complete the *service* for the tendered total of the Prices.

3 There is no adjustment to lump sum prices in the *price list* if the amount, or quantity, of work within that lump sum item of service later turns out to be different to that which the *Contractor* estimated at time of tender. The only basis for a change to the Prices is as a result of a compensation event. See Clause 60.1.

4 Hence the Prices and rates tendered by the *Contractor* in the *price list* are inclusive of everything necessary and incidental to Providing the Service in accordance with the Service Information, as it was at the time of tender, as well as correct any Defects not caused by an *Employer's* risk.

5 The *Contractor* does not have to allow in his Prices and rates for matters that may arise as a result of a compensation event. It should be noted that the list of compensation events includes those arising as a result of an *Employer's* risk event listed in core clause 80.1.

Format of the *price list*

(From page 76 of the TSC3 Guidance Notes)

Entries in the first four columns in the *price list* in section C2.2 are made either by the *Employer* or the tendering contractor.

If the *Contractor* is to be paid an amount for the item which is not adjusted if the quantity of work in the item changes, the tendering contractor enters the amount in the Price column only, the Unit, Expected Quantity and Rate columns being left blank.

If the *Contractor* is to be paid an amount for an item of work which is the rate for the work multiplied by the quantity completed, the tendering contractor enters the rate which is then multiplied by the Expected Quantity to produce the Price, which is also entered.

If the *Contractor* is to be paid a Price for an item proportional to the length of time for which a service is provided, a unit of time is stated in the Unit column and the expected length of time (as a quantity of the stated units of time) is stated in the Expected Quantity column.

C2.2 Price List

The following Activity Schedule is provided “as-is” for the benefit of the Bidder. ACSA (the Employer) cannot guarantee that it is complete in all respects. The Bidder is responsible for providing an Activity Schedule which is accurate, complete and in accordance with their proposal. Also, refer to C3 (Service information) for activities that need to be priced. Only items listed in this Activity Schedule may be billed to the Employer. All rates to exclude vat.

ACSA reserves the right to vary all the activities according to the rates given in this contract.

Part 1 - Activity Schedule

Item no.	Activity Description	Frequency	Quantity (per 6 months)	Amount (per single item)	Total (per 6 months)
Preliminary and General					
1	Airport personal permits and vehicle permits – provisional sum (Estimated on 20 resources and 2 vehicle required on site)	Once off	1		
2	Operations Vehicle Parking fees – provisional sum Please refer to calculation below to obtain monthly rate	Monthly	6		
3	Contract Management, Administration, Store supervision and Monthly reports	Monthly	6		
4	Insurance (All ACSA-required reinsured items as per the insurance schedule (C1.5) for the duration of this contract)	Monthly	6		
5	PPE and Cell phone	Once off	1		
Total Preliminary & General					R
Maintenance & Inspections					
6	Daily Inspections	Daily	180		
7	Monthly Preventative Maintenance	Monthly	6		
Total Maintenance & Inspections					
Total	Sub-total A (Total Preliminary & General + Total Maintenance)				R

The above activity schedule is minimum work required and the contractor as the subject expect matter on these services they are bidding for **shall fill in any other activity with prices for “other” activities which they deem necessary to achieve the set out comes on availability, reliability, maintainability, MTTR, MTBF, legislative and all other targets set in this contract. **Should an alternative not be presented, the offer will be deemed as the contractor’s optimal proposal for which they will be liable for.***

****All rates for all activities including diagnostic and repair shall include all required tools, software, hardware and consumables (including all applicable specialized tools and software, hardware and consumables) Onus is on the contractor to price correctly).**

*****It is noted that the required labour resources and skills for this contract is not prescribed in detail. The contractor is fully responsible to ensure that labour resources remain adequate and competent in order to maintain required service levels, system performance levels and according to all applicable laws and regulations. The Tenderer shall also ensure that all required maintenance is catered for as per the Original Equipment Manufacturer in the pricing above.**

******Low service damages will be applicable as per the Low service damages table in this contract**

Calculation of monthly rate for operations vehicle parking fees		
Monthly Rate (per vehicle)	No. of vehicles to be used	Total rate per month for payment of parking fees (monthly rate x no. of vehicles)
R 1 300.00		NB: This amount to be carried over to Table A in the column name “Amount (per single item)” for item 2 for calculating the Total Preliminary and General.

Labour rates and Mark-up

Any work not included under part 1 shall be deemed additional work or non-scheduled items and will be charged at the following rates:

Activity Schedule – part 2 (Labour rates and Mark-up - Breakdowns)

Any work not included under part 1 shall be deemed additional work or non-scheduled items and will be charged at the following rates:

*All rates to exclude vat. Subject to mutual agreement between ACSA and the Contractor, the number of staff allocated to the contract may be increased/decreased to cater for special needs that may arise from time to time.

Labour rates shall include all personnel insurance, holidays with pay, incentive bonuses.

Note: No labour shall be charged for travel or travelling. Labour time shall be calculated for the time spent on site.

Call out rate must include all required travelling and the first hour on site.

i) LABOUR RATES: (to be filled in)

Item	Description	Weekdays after hours(R/hour)	After hours (R/hour)	
			Saturday	Sunday/public holiday
1	Site Manager			
2	Technician			
3	Technician assistant/ Semi-skilled labour			
4	Other specify:			
5	Other specify:			

Detail requirements regarding staff

The Contractor shall continuously ensure that all staff is suitable, able and competent for the duties required of them. Staff must have experience and applicable competencies as per OEM and all legislations in the maintenance and/or installation of Roof Ventilators and HVAC Mechanical Systems. The Contractor shall continuously ensure that all staff is knowledgeable on all equipment relating to the Roof Ventilators and HVAC Mechanical Systems.

Note the following minimum below:

SITE MANAGER/TECHNICIAN

- The ability to prepare comprehensive reports, sign off all maintenance records and verify that the systems are safe and fit for use on monthly basis.
- Should have working experience in the maintenance and/or installation of Roof Ventilators, HVAC Mechanical Systems or similar works.

TECHNICIAN /TECHNICIAN ASSISTANT

- Properly trained and competent in category of work that he is required to perform.
- Should have working experience in the maintenance and/or installation of Roof Ventilators, HVAC Mechanical Systems or similar works.

Note the following minimum below as per standardised Mechanical resources per infrastructure:
Each site to maintain a technician and assistant. Filter cleaner and assistant for all sites.

Area/Sites	Administrator/ Storeman	Site Manager	Fitter	Refrigeration Mechanics	Assistants
Central Terminal Building	1	1	3	1	2
Domestic Terminal, Domestic Pier and Multi Storage Parking 1				1	2
International Terminal, International Pier, KB1 and KB2, & Multi Storage Parking 2				1	4
Cargo, Freight Agent Building, ATNS & Airside				1	2
Western Precinct Building				1	2
Total	1	1	3	5	12

ii) **CALL OUT FEE**

NOTE:

- All rates for all activities including diagnostic and repair shall include all required tools, software, hardware and consumables (including all applicable specialized tools and software, hardware and consumables) Onus is on the contractor to price correctly).
- All *call out* shall include all applicable travelling, all personnel insurance, holidays with pay, incentive bonuses etc. Labour laws and all applicable laws shall be followed by the contractor.
- Call outs are not chargeable during hours technician/artisan/assistants or any applicable resource are on site.
- Call outs are not chargeable during working hours' technician/ assistants are on site (07:00 – 17:00)

- e) Staff compliment from 17:00 to 05:00 (Mon-Fri) and 24 hours on weekends and public holidays to be deployed, 1 technician and 1 assistant per shift.
- f) The contractor will be compensated according to the contractor's repair rate provided in the below table B and it is subject to discussion with the service manager due to proven factors that are beyond the contractor's control (some of the internal and external factors are listed in Annex T).
- g) Call-out remuneration is applicable to activities falling out of preventative maintenance activities that were supposed to be done by the contractor, thus ACSA will not pay for breakdown which are due to preventative maintenance negligence by the contractor.

Table B: Call outs + Labour

Description	Quantity / 6 months	Call out fee	Total/ duration
Call out including first one (1) hour on site and travelling fee (Weekends or Public Holidays or After hours)	20		
*Total Call out Fee			R
Sub-total B (*Total Call out Fee)			R

iii) SPARES and MARK-UP

***Spares** will be managed using ACSA's manual inventory management system.

The manual inventory management system will include but not limited to;

- Conducting and submission of monthly and quarterly stock count to the Service Manager by the contractor,
- Keeping up-to-date inventory cards by the contractor,
- Management of spares movement by the contractor,
- Keeping an up-to-date inventory file (purchase order and request, work order, delivery note, stock count records, etc.).
- Ensure safety and security of the storeroom by the contractor as per space given to them.
- The space for spare storage shall be allocated by ACSA to the contractor and can be a shared space as per space availability.
- Management of inventory by the contractor as per ACSA inventory procedure

Spares:

Description	Total (excluding VAT)
Subtotal C- provisional sum for spares	R900 000-00

Mark-up (third party procured items/services)

Bidder to complete.

Value of Item or Services	**Mark-up (Contractor to fill in)	Spares amount for budget purposes *Z*	Total mark-up values to be budgeted- (Contractor to fill in) = (*Z*x Y)
R0 - R2,000	%	R2 000.00	
R2,001 - R5,000	%	R5 000.00	
R5,001 - R10,000	%	R10 000.00	

R10,001 - R50,000	%	R50 000.00	
Sub-total D (Third party Mark-up) (Note: Should be part of the form of offer and acceptance)			R

^bCost shall be net cost (excluding VAT) of parts delivered to site with all discounts deducted.

**The inserted amount *Z* are for budgeting purposes. The Total mark -up amount in the table is not guaranteed, but the mark-up will be applicable on third party quotations as per requirements of the system. Thus, the contractor will be held accountable to the mark-up filled in this table.*

***The mark-up will be applicable to the total of the third-party quotation not on a single line items in a quotation.*

Contract value

Below, the guide that must be used in estimating the contract value. This amount must be reported as the Contract Value in the corresponding schedules. Tenderers are reminded that this amount is for illustrative purposes only and that ACSA will not be under any obligation to expend the full or any portion of this amount. Monthly contract expenditure will be strictly calculated according to the Activity Schedule as provided above.

Maintenance of Roof Ventilators and HVAC Mechanical Systems at O.R. Tambo International for a period of 6 months

Description	Total (excluding VAT)
Sub-total A (Total Preliminary & General + Activity Schedule)	R
Sub-total B (*Call out fee)	R
Sub-total C (Spares provisional sum)	R900 000.00
Sub-total D (Third party Mark-up)	R
*Total E- Total maintenance cost for <u>6 months</u>	R

Note:

***TOTAL- E** (i.e. Total maintenance cost for duration of the contract) must be carried to the form of offer and acceptance

The values in this table/contract are not guaranteed, payment will be done as per approved work/activity done and assessments in this contract.

C3 Service Information

DESCRIPTION OF THE WORKS

Employer's objectives

The objective is to provide service of Maintenance of Roof Ventilators And HVAC Mechanical Systems at OR Tambo International Airport in a sustainable manner at the lowest operating and maintenance costs while ensuring compliance to general safety and aviation related legislation. The Contractor will be appointed directly by the Airports Company of South Africa.

The Contractor will provide Maintenance of Roof Ventilators and HVAC Mechanical Systems at O.R. Tambo International Airport for a period of 6 months. The specifications and requirements in this document comprise the description of the Works. The Contractor will be appointed directly by the Airports Company of South Africa.

Onus is on the contractor to provide assurance that competent persons would be carrying out all tasks in accordance to all the applicable standards, OEM requirements, procedures, regulations and legislative requirements.

Scope of work (OPEX)

The *Contractor* will provide maintenance Services for Roof Ventilators and HVAC Mechanical, infrastructure which is located on the landside and airside of OR Tambo International Airport including Western Precinct Building (Aviation Park). The specifications and requirements in this document comprise the description of the *Services in Annex A*.

Equipment Life Span

- ❖ The life span of the Roof Ventilators, HVAC Mechanical Systems is 5 years (refer to **Annex C** for the list and life span)
- ❖ The list of equipment commissioning dates has been provided on **Annex B**.

OEM Requirements

The O.E.M recommended the below preventive maintenance for the Roof Ventilators, HVAC Mechanical Systems:

- ❖ Quarterly maintenance
- ❖ Bi- annual maintenance
- ❖ Annual Maintenance

ACSA: O.R Tambo international Airport has since implemented daily inspections for the Roof Ventilators, HVAC Mechanical Systems.

Condition of the plant

The maintenance history of the equipment has been logged with ACSA Integrated maintenance centre.

- ❖ The list breakdowns and faults experienced and the estimated time for repair on the Roof Ventilators, HVAC Mechanical Systems are listed on **Annexure H**.

- ❖ The preventative maintenance previously performed on the Roof Ventilators, HVAC Mechanical Systems are listed on **Annex F**, for the actual work orders with tasks, ACSA Integrated maintenance centre can be contacted to issue actual.
- ❖ A sample of root cause analysis on the Roof Ventilators, HVAC Mechanical Systems has been attached on **Annex G**. Also, the root cause analysis must be performed, and the Root cause analysis form completed by the contractor and handed over to ACSA service manager after each breakdown.

Site Information

- ❖ The Roof Ventilators, HVAC Mechanical Systems are located at on the airside and landside at O. R. Tambo International Airport including the Western Precinct Building (Aviation Park) (refer to Annexure A for a full list of equipment).
- ❖ The airport layout and site information has been provided on **Annex D**.

Minimum work requirements and Legislations:

Maintenance of Roof Ventilators, HVAC Mechanical Systems shall as minimum conform to the following Procedure and or other legislative references (Gazetted Standards or OHS Regulations):

- ❖ ACSA maintenance procedure for Roof Ventilators, HVAC Mechanical Systems - as provided in **Annex N**.
- ❖ The preventative maintenance previously performed on the Roof Ventilators, HVAC Mechanical Systems are listed on **Annex F**, for the actual work orders, ACSA Integrated maintenance centre can be

Note: above is the list of minimum regulations and legislative requirements that the contractor needs to adhere to as mandatory requirements (**work should be carried out by competent people as prescribed in the law and shall be auditable by the employer at any given time**)

Access to site

- ❖ Airside training and permit should be completed and issued before accessing airside and commencement of work.
- ❖ AVOP training and permit should be completed and issued before the commencement of work for personnel driving required to drive on airside.
- ❖ Permission must be obtained from ACSA operations and IMC before an equipment can handed over to the contractor for works and such arrangements must be done prior and timeously.

Site Restrictions

- ❖ Airside training and permit should be completed and issued before accessing airside and commencement of work.
- ❖ AVOP training and permit should be completed and issued before the commencement of work for personnel driving required to drive on airside
- ❖ The safety file should be completed and approved by the safety department before commencement of work. The safety file is a living document and must be continuously updated with all requirement as specified by law. Also, will be auditable from time to time.
- ❖ Personal Protective Equipment should be issued before the commencement of work.

Risk

The are some of the risks identified but not limited to the below and to **Annex E** list.

Current Guarantees and warranties to be maintained:

- ❖ Annex W - N/A

Extent of the works

The Contractor will be fully responsible for meeting all requirements in this document regarding the Works.

For each piece of equipment, all work will be carried out to standards as required by the Original Equipment Manufacturer (OEM) as well as any applicable governing law and/or regulations. Where OEM standards differ from those required by this document the more stringent requirement shall apply. The Contractor will be fully responsible for obtaining (and keeping up to date with) said requirements.

Where, such a need is mutually agreed between the Contractor and the Employer, the Employer shall put in place a "Hotline" (i.e. 24-hour telephonic support by product specialist) agreement with the relevant OEM. In this event the Contractor shall be responsible that such Hotline services are always operational and available, but all costs in this regard shall be carried by the Employer. The Contractor shall NOT add any mark-up to any Hotline related expenses. A "Hotline" agreement shall typically ensure that problems relating to system controls are promptly rectified. It is intended that Hotline agreements will be in place with OEMs for PLC related controls and computerised control systems.

The Contractor will be responsible for providing staff which are sufficiently skilled and qualified for successful execution of the works. The Contractor shall comply with the Minimum Staffing Schedule always – as stipulated in the Annexes. This may be amended by mutual arrangement between the Employer and the Contractor from time to time.

The Contractor shall always remain responsible to ensure that the on-site staff compliment and maintenance regime is sufficient to maintain the service levels and system performance indicators as stipulated in the Annexes. Should the Contractor not be able to maintain adequate system performance indicators due to constraints caused by the Employer, it shall be timeously reported, in writing, to the Contract Manager. Refer to the Annexes for the required system performance indicators.

The Contractor will ensure that his/her staff compliment is of a sufficient quantity to allow for uninterrupted supply of labour in the event of his/her staff taking sick leave, paid leave and will allow for all staff related eventualities.

The Contractor shall continuously ensure that all staff is suitable, able and competent for the duties required of them. The Contractor shall continuously ensure that all staff is knowledgeable and dependable in Roof Ventilators, HVAC Mechanical Systems maintenance activities/procedures in the area. The Contractor shall further ensure that any staff member reasonably suspected of partaking in criminal activities is immediately removed from site and his permit returned to and/or cancelled at the ACSA Permit Office.

All work shall be performed within the required Response Times – as stipulated in the Annexes. Any breakdown impacting on operations shall be attended-to until restored to good reliable condition. No breakdown may be left unattended or incomplete for the next day or shift. All repair work shall carry a defect free be guaranteed for a period of 3 months after completion of work.

All work shall be charged according to the Activity Schedule. However, no labour shall be charged for any non-scheduled work, repair work or other work when carried out by a scheduled maintenance shift.

The Contractor will be responsible for keeping spares levels up to a sufficient quantity and standard as to comply with the requirements of this contract and will charge the Employer accordingly. All spares will be charged according to the Activity Schedule. The Contractor shall arrange for the spares room. The Contractor shall keep the spares room in a neat and clean state and an updated spares list will always be available on-site. Spares will be neatly arranged and easily locatable via an appropriate index on the spares list. Wherever practicable, a notice will be placed on the rack, next to the spare part, as to where the part is used in the installation. A resource will be dedicated to ensuring that spares are effectively



managed and scrapped parts and waste removed from site. The space for spare storage shall be allocated by ACSA to the contractor and can be a shared space as per space availability.

The Contractor will be responsible for holding all tools and/or special equipment that might be required for the execution of the works, either on site or on their premises in order to comply with the Response Time requirements of this contract. Any exclusion to the above should be clearly communicated in the returnable schedules when submitting the tender.

The Contractor shall ensure that, unless a special arrangement is made with the Service Manager, all senior staff members and on-site support staff is always immediately reachable via cell phone.

The Contractor shall ensure that all maintenance staff are issued with uniforms that will comply with a minimum requirement as agreed with the Service Manager from time to time. Current airport requirements are safety shoes, track suit and a uniquely numbered reflective jacket (for easy identification via CCTV).

Location of the works

The Works are located at O. R. Tambo International Airport at various locations, including the Western Precinct Building (Aviation Park) – mostly in controlled areas. It is crucial for the Contractor to note that O. R. Tambo International Airport is a National Key Point and governed as such.

PROCUREMENT

Preferential procurement procedures

Requirements

The Contractor will respect OEM warranties to the Employer always when procuring spare parts, products or 3rd party services. It will be the Contractor's sole responsibility to ensure that OEM warranty requirements are adhered to always.

Where Contractors use or quote on spare parts of a lower quality than recommended by the OEM, or parts not recommended by the OEM, this shall be clearly indicated to the Service Manager on the quotation. This also implies that the Contractor must build relationships with the various key OEM's.

The Contractor must adhere to all airport requirements regarding fire, health and safety when procuring replacement conveyor belts and/or other equipment or spares.

No casual labour (i.e. "off the street" labour) may be employed by the Contractor unless pre-arranged with the Employer. Whenever this is required, the Contractor shall come to a suitable arrangement with the Employer regarding sourcing and screening of such individuals.

Subcontracting

No part of this Contract may be subcontracted unless with written approval from the Employer. the Employer shall be under no obligation to grant such approval. Should any part of this Contract be subcontracted, the Contractor will be responsible for all Works (or failure to affect the Works) as if it was done so by the Contractor.

MANAGEMENT

Management of the works

Particular / generic specifications

All work shall conform to all relevant SANS standards, OHS ACT regulations and all other legislation that might be relevant to this Contract and the execution thereof.

All work shall be carried out in accordance with prevailing industry norms and best practice and will always comply with OEM requirements.

Planning and programming

All maintenance work shall be scheduled, and a roster presented to the Service Manager at the end of the preceding month. Work shall be scheduled in a manner as not to interfere with any normal airport operations.

Normal airport operational hours shall be **from 04:00 to 24:00** for every day of the year.

As a **minimum** requirement, the Contractor shall roster **scheduled** preventative maintenance activities.

Maintenance teams will attend to scheduled preventative maintenance, non-scheduled maintenance and breakdown maintenance. The Contractor must ensure that no scheduled maintenance work is carried over to the following week.

All Preventative Maintenance shall be scheduled, at least, to the requirements of the annexures (The Contractor must ensure that sufficient allowances for all these items are made with his/her pricing in the Activity Schedule.)

Methods and procedures

The Contractor must accept and respect the fact that the Airport is continuously undergoing construction and improvement and that a variety of stakeholders are involved in the Employer's business. Therefore, within reason and with prior arrangement with the Contractor, the Employer might require the following from time to time:

- Assisting with emergency repairs on
- Assisting with airport operations Re-scheduling of work to accommodate other contractors
- Allowing access and providing assistance to OEM suppliers to correct defects on equipment and/or systems
- Checking on other contractors in order to reduce risk to Roof Ventilators, HVAC Mechanical Systems
- Pointing out services to consultants or other contractors
- Providing access to other contractors
- Attending co-ordination and planning meetings
- Removing rubble and/or equipment from site
- Training of ACSA operators and/or technicians
- Training of check-in of Roof Ventilators, HVAC Mechanical Systems staff
- Providing of system data and/or statistics to ACSA
- Recommending improvements on maintenance procedures



- Recommending improvements on operational procedures
- Co-operating with ACSA Security relating to security issues
- Safe / legal disposal of used and irreparable spares

The Service Manager may instruct operational and works procedures to the Contractor as might be required from time to time. The Contractor will instruct his/her staff accordingly and implement measures to ensure that these procedures are strictly adhered to.

Quality plans and control

All work must be executed in accordance with prevailing industry norms and standards relating to quality. In this regard, the Contractor will be expected to draft quality plans for the Service Manager from time to time. Emphasis must be on improving system reliability and on ensuring that rostered maintenance work is indeed performed as and when required.

Environment

The Contractor will keep noise and dust levels to a minimum. At no time, shall his/her work result in nuisance, interference or danger to the public or any other person working at the Airport.

At no time, shall the Contractor:

- allow any pollutive or toxic substance to be released into the air or storm water systems
- interfere with, or put at risk, the functionality of any system or service
- cause a fire or safety hazard

Format of communications

Work instructions, daily check sheets, monthly maintenance reports, inventory reports, breakdown reports, exception reports, etc. will all be in a format as agreed with the Service Manager.

Key personnel

A schedule of key personnel to this Contract (as per the Schedules) will be provided to the Service Manager at commencement of this Contract. This will, as a minimum, include all persons from technician level to management level. For the full duration of this Contract, none of these persons will be replaced by a person of lesser ability or qualification. All on-site staff leaves shall be reported and agreed with the Service Manager.

Management meetings

The Contractor will be expected to attend meetings relating to maintenance, operations, contract management and other issues that may arise from time to time. As far as is practicable, the Contractor will make all required persons available for these meetings. The Contractor shall not submit claims for payment for staff attending any of these meetings.

Electronic payments

The Contractor should arrange with the Employer's finance department for making all payments electronically.

Daily records

The Contractor shall keep accurate daily records of staff attendance, maintenance work, safety inspections and exception reports. Records shall be available for scrutiny by the Service Manager at any time. All records shall be in a format as agreed with the Service Manager.

Monthly reports

When invoicing, the Contractor shall ensure that all required reports for the corresponding month are attached to the monthly invoice. This will include monthly reports on but not limited to:

1. system availability (averaged per week)
2. maintenance work (including % of scheduled maintenance work completed)

3. daily checks performed
4. maintenance plan for the next month
5. the latest spares inventory
6. Assets register up to date including equipment data
7. Root cause analysis records
8. Safety/Environmental or legislative issues and compliance
9. Outstanding maintenance issues

The Contractor shall keep copies of all reports and records for at least 3 years. All reports shall be in a format as agreed with the Service Manager from time to time.

Permits

The Contractor shall not be compensated for costs relating to the Employer's required permits, or for labour/time spent in obtaining it. An allowance must be made in the Activity Schedule in this regard.

The Contractor must ensure that he/she is, always, familiar with the Employer's safety and security requirements relating to permits for no work to be delayed as a result thereof. This will include the permit application process.

Note that (within reason) the Contractor will have no claim against the Employer if a permit request is refused.

The following table is not all inclusive, but is provided for illustration purposes:

Permit	Required by/for	Department
AVOP – Airside Vehicle Operator permit	All drivers of vehicles on airside	ACSA Safety
Airside Vehicle Permit	All vehicles that enter airside	ACSA Safety
Basement Parking permit	All vehicles allowed to enter the delivery basement	ACSA Parking
Personal permit	All persons employed on the airport	ACSA Security
Cell phone permit	All persons taking cell phones to airside	ACSA Security
Lap top permit	All persons taking lap top computers to airside	ACSA Security
Camera permit	All persons taking cameras or camera equipment to airside	ACSA Security
Hot Works Permit	All welding and/metal cutting work	ACSA Safety

Proof of having attended the airside induction training course is required for all personal permit applications. Persons applying for an AVOP must provide proof of having attended an AVOP course. Fees are levied for these courses. Fees are further levied for all permit renewals and refresher courses - where applicable.

Proof of compliance with the law



The Service Manager may at any time request from the Contractor reasonable proof that the Contractor is in compliance with a law or regulation.

Health and safety

Health and safety requirements and procedures

The Service Manager shall be entitled to fine the Contractor low service damages for each non-conformance to Health and Safety matters. This shall not transfer any of the Contractor's responsibilities in this regard to the Employer by any means.

The Contractor shall be fully responsible for compliance to the Occupational Health and Safety Act for all persons, equipment and installations relating to this Contract. The Contractor is expected to sign the undertaking in this regard as attached in the annexes.

It shall be the Contractor's responsibility to ensure that all relevant labour and safety legislation is adhered to in rostering staff.

All persons on company premises shall obey all health and safety rules, procedures and practices. NO SMOKING signs and the prohibition of the carrying of smoking materials in designated areas shall always be obeyed. A copy of the Safety Rules booklet is available on request from the ACSA Safety Department.

All the applicable requirements of the Occupational Health and Safety Act (1993) and Regulations and any amendments thereto, shall be met. Where the OHS Act prescribes certification of competency of persons performing certain tasks, proof of such certification shall be provided to the Service Manager.

The Contractor's Workmen's Compensation fees must be up to date. A copy of the Contractor's WCA registration shall be produced on request.

The following areas in the company are declared as "HOT WORKS PERMIT" areas:

All airside areas

All basement areas

All areas accessible to the public

All enclosed areas

The terminal building

Any process in the above-mentioned areas involving open flames, sparks, or heat shall be authorised by the issue of a permit to work - obtainable from the ACSA Safety department. Any work done under the protection of a permit to work shall be in strict compliance with every prescription regarding the permit.

Safety equipment shall be used where applicable (e.g. safety, goggles, boots, harness, etc.) The Contractor, at his/her own expense shall provide such equipment, for his/her employees. The Contractor shall apply the necessary discipline and control to ensure compliance by his workers.

All Contractors must ensure that his/her employees are familiar with the existing emergency procedures and must co-operate in any drills or exercises, which might be held. Emergency / fire equipment and extinguishers shall not be obstructed at any time

No person shall perform an unsafe / unhygienic act or operation whilst on Company premises.

No unsafe/dangerous equipment or tools may be brought onto or used on Company premises. The Company reserves the right to inspect all equipment/tools at any time and to prevent/prohibit their use, without any penalty to the Company and without affecting the terms of the Contract in any way.

The Company reserves the right to act in any way to ensure the safety/security of any persons, equipment or goods on its premises and will not be liable for any costs or loss evoked by the action. This includes the right to search all vehicles and persons entering, leaving or on the premises and to inspect any parcel, package, handbag and pockets. Persons who are not willing to permit such searches may not bring any such items or vehicles onto the premises.



The Contractor shall maintain good housekeeping standards in the area where he is working for the duration of the contract.

At no time, must the Contractor interfere with, or put at risk, the functionality of any Sprinklers and/or fire prevention system. Care must also be taken to prevent fire hazards.

The Contractor is required to issue all staff with standard uniforms. This shall as a minimum include steel-tipped safety shoes/boots, overalls (clearly marked with Contractor's company logo) and numbered reflective jackets (also clearly marked with Contractor's company logo, the team members unique personnel number in a font size to be instructed by the Service Manager). All costs relating to uniforms shall be for the Contractor's account.

Cell phones and two-way radios

Use of cell phones on airside is **not** permitted unless the user is in possession of an appropriate Airport permit for the device. Cell phone permit issuing authority lies with the ACSA Security department.

The Contractor will **not** be allowed to use two-way radios at the Airport unless these radios are of the type, model and frequency range as approved by the ACSA IT department.

Protection of the public

The Contractor shall take special care in order not to harm or endanger the public in any way. Work shall be sufficiently hoarded and guarded to safeguard children and the general public from injury relating to machinery, work or other.

Barricades and lighting

Where hoarding, barricades or lighting is required in the execution of the Works, the Contractor shall provide same at his/her own expense. Hoarding, barricades and lighting shall comply with industry accepted norms and standards and may not be used for purposes of advertising or any other purpose than safeguarding the Works.

Enterprise and Supplier Development Initiatives

It is a requirement of this project that the successful tenderer enters into a contract (either through partnership, joint ventures or sub-contractors) with Targeted Enterprise(s) as defined in the Contract Data to perform a minimum of Thirty percent (30%) of the tendered contract value.

Tenderers must state transformation deliverables that are both achievable and measurable as the successful tenderer will be required to issue comprehensive monthly reports in response to this tender requirement. The monthly report will be assessed by ACSA's Internal Transformation Committee, which is accountable for implementation of ACSA's Transformation initiatives.

C3.2.1 Definition of a Targeted Enterprise

A registered built environment professional firm contracted (either by Joint Venture, partnership or sub-contracting) by the tenderer to perform a specified percentage of work stated in the Contract Data under the guidance of the tenderer and which complies with the following:

- a) does not share equity holding with the tenderer; and
- b) is registered in terms of the Company's Act, 2008 (Act No. 71 of 2008) or Close Corporation Act, 1984 (Act No. 69 of 1984); and
- c) is registered with the South African Revenue Service; and



- d) is at least an Exempted Micro Enterprise (EME) with a B-BBEE Status of “Level One Contributor”, as defined in the Amended Codes of Good Practice for measuring Broad-based Black Economic Empowerment (published in Government Gazette No. 36928 on 11 October 2013) or?
- e) is at least a Qualifying Small Enterprise (QSE) with a B-BBEE Status of “Level One Contributor”, as defined in the Amended Codes of Good Practice for measuring Broad-based Black Economic Empowerment (published in Government Gazette No. 36928 on 11 October 2013).
- f) has entered into a written relationship agreement of co-operation and assistance with the tenderer for the duration of the contract.

C3.2.2 Participation of Targeted Enterprise(s)

The involvement of Targeted Enterprise(s) in the project management, manufacturing and testing is a mechanism to broaden the economic share of the national spend on engineering services and a means to hasten and improve the transfer of technical skills.

The percentage specified for Targeted Enterprise shall be applicable to the management, manufacturing and testing aspects of the project.

C3.2.3 Transformation monthly reporting

The tenderer shall report monthly and provide the following documents:

- The skill development or transferred during the month in question and
- The progress of the targeted enterprises skill development.
- Proof of payment to the target enterprise

C3.2.4 Sanctions for non-compliance with the transformation proposal

In the event that the tenderer does not meet the specified target of work value to the Targeted Enterprise, ACSA shall levy a penalty. The penalty payable is 50% of the value by which the cumulative value of the payments to the Targeted Enterprise fails to meet the specified percentage. The Targeted Enterprise(s) shall not be allowed to sub-contract any work that forms part of the specified participation percentage.

ANNEXES to C3 (Service information)

Title	Annex number	Applicable or N/A
Schedule of Equipment	Annex A	Applicable
Equipment commissioning dates	Annex B	N/A
Equipment life span	Annex C	N/A
Site information	Annex D	Applicable
Risk assessment	Annex E	Applicable
Previous completed PMs	Annex F	N/A
Root cause analysis	Annex G	Applicable
Estimated times for breakdowns/faults	Annex H	Applicable
Key Performance Indicators	Annex I	Applicable
OHS Act Appointment by Contractor	Annex J	Applicable
Minimum Maintenance Programme	Annex K	Applicable
Environmental Terms and Conditions	Annex L	Applicable
Maintenance of Roof Ventilators, HVAC Mechanical Systems Spares List	Annex M	Applicable
ACSA maintenance procedure for Roof Ventilators, HVAC Mechanical Systems	Annex N	Applicable
Roof Ventilators, HVAC Mechanical Systems – standard operating procedure	Annex O	N/A
Roof Ventilators, HVAC Mechanical Systems – Electrical lockout procedure	Annex P	N/A
O.R. Tambo International Airport – operating instruction for Roof Ventilators, HVAC Mechanical Systems	Annex Q	N/A
Roof Ventilators, HVAC Mechanical Systems - Fire Emergency procedure	Annex R	N/A
IMCC procedure	Annex S	Applicable
Internal and external factors outside the contractor's control	Annex T	Applicable
ACSA Mechanical Standardised Minimum: legal requirements and minimum competency requirements	Annex U	Applicable
ACSA Inventory management procedure	Annex V	Applicable
Guarantees and warranties to be maintained	Annex W	N/A

ANNEX A**SCHEDULE OF EQUIPMENT**

The tender must not that this is a close estimate of the number of equipment and systems on site.

Equipment

No	Description	Cargo	CTB	Domestic	International
1	Chillers	1		5	7
2	Cooling towers	1		4	7
3	Air handlers and Dampers	375	74	131	237
4	Pumps	7		15	35
5	BMS		1	1	2
6	Total	384	75	155	372
7	Energy management system			1	

Note: Split units, package units, VRV units and other are part of the scope but are not included in this schedule of equipment because they form a small percentage of the scope.

	Model Number	Cooling capacity KW	Original reference number
1	RTHB	867	Agent Building (83C432)
2	RTHC - Domtex	1493.8Kw	Domtex (83G122)
3	RTHC - Domtex	1493.8Kw	Domtex (83G122)
4	RTHC - Domtex	1493.8Kw	Domtex (83G122)
5	RTHC - Domtex	1493.8Kw	Domtex (83G122)
6	RTAD - Data	258.4	Domtex (83G122)
7	CVGF 800 - Chiller 1 – KB2	2999.85	OR Tambo Basement 83G424
8	CVGF 800 - Chiller 2 – KB2	2999.85	OR Tambo Basement 83G424
10	CVGF 800 - Chiller 3 – KB2	2999.85	OR Tambo Basement 83G424
11	CVGF 800 - Chiller 4 – KB2	2999.85	OR Tambo Basement 83G424
12	RTHD - Chiller 5 – KB2	1214.08	OR Tambo Plantroom (83G424)
13	CVGF 800 - Chiller 6 – KB2	2999.85	OR Tambo Plantroom (83G424)
14	CVGF 800 - Chiller 7 – KB2	2999.85	Or Tambo Plantroom (83G424)

ACSA - Equipment No: (Cooling Tower)	Model no:		
1	AT 112-814	Evapco	International
2	AT 112-814	Evapco	International
3	AT 112-814	Evapco	International

4	AT 112-814	Evapco	International
5	AT 19-311	Evapco	
6	AT 112-814	Evapco	International
7	AT 112-814	Evapco	International
8	ATW 102K-4K	Evapco	Agent Building
9	LRT8-122	Evapco	Domestic
10	LRT8-122	Evapco	Domestic
11	LRT8-122	Evapco	Domestic
12	LRT8-122	Evapco	Domestic

Number	Description	Quantity	Type	Area
1	Roof ventilators	444	Fusible link, louvre	Flat Freight
2	Roof ventilators	14	Pneumatic, dome	Perishable Cargo Triangle
3	Roof ventilators	98	Pneumatic, dome	ACSA administrative building, 3rd and 4th floor
4	Roof ventilators	54	Electrical with fusible link, louvre	West wing (airline) offices, 3rd floor
4	Roof ventilators	8	Electrical with fusible link, louvre	DHL Cargo
5	Roof ventilators	18	Fusible link, louvre	Northern International Pier
6	Compressors	1	1000l, electrical	ACSA administrative building
7	Compressors	1	240l, electrical	Perishable Cargo Triangle

Western Precinct

No	Description	Quantity
1	Air-cooled Chillers	3
2	Water-cooled Chillers	2
3	Cooling towers	2
4	Pumps	17
5	Fans	13
6	Fan Coil Units	108
7	Split Units	18
8	Air Handling Units	10
9	CO & CO2 Sensors/Detectors	93
10	BMS Control Panels	28
11	Electrical Motor Control Panels	46



ANNEX B

Equipment Commissioning Dates

N/A



ANNEX C

Equipment Life Span

N/A

**ANNEX D****Site Information****Description**

The *services* are situated on the airside of O. R. Tambo International Airport.

General Site Conditions

Temperature (Min - Max)	6°C to 40°C
Relative Humidity	15% to 60%
Wind	28m/s
Height above Sea Level	1,680 m
Slope (Existing/Modified)	Level
Seismic	N/A



ANNEX E**Risk assessment****OHS Risks**

Available from the Service manager on request

Administrative Risks

Risk Number	Risk Description and mitigation measures
1	Safety File not being 100% compliant or safety/environmental infringement could lead to the contractor being taken off site
2	Expired COIDA letter; contractor will be taken off site.
3	Insufficient resources on site to perform the work required roster; contractor will be penalized accordingly
4	Failure to annually present a compliant Tax Clearance Certificate which is considered a material breach of the conditions of this Contract
5	Not meeting set availability target; contractor will be penalized and failing rehabilitation contract will be terminated as specified in this contract
6	Not meeting set MTTR target; contractor will be penalized and failing rehabilitation contract will be terminated as specified in this contract
7	Spares list not being updated could lead to extended equipment down times; contractor will be penalized and failing rehabilitation contract will be terminated as specified in this contract
8	Root cause analysis not performed could lead to repeated equipment failures; contractor will be Low service damages will be imposed and failing rehabilitation contract will be terminated as specified in this contract
10	Failure to annually present compliant BEE certificate which is considered a material breach of the conditions of this Contract
11	Contract value being expended before contract expiry date; contract will be terminated
12	Contractor not giving documentation for work assessments and payment on time; Contractor will not be paid on time
13	Updated and compliant safety file regarding Covid 19 PPE and risk assessment, as per OHS and regulation.
14	Any change in the law that is reinforced as per clause X2(Changes in the law)
15	Department of labour as an Electrical Contractor



ANNEX F

Previously completed PMs

N/A

ANNEX G

Root cause analysis

Root cause analysis must be done for each failure and the form is per below must be handed over after closing any works.

ORTIA ME Root Cause Analysis Sheet							
Function failure (Which function was no longer execute) The bridge could not drive due to torn wheel.		Alpha 12 passenger loading bridge was not moving due to wheel puncher		Date: 2 December 18	Time of incident:	Reported by/Operator: MCS, Thulelele	
Asset class: AIRBRIDGE - APRON DRIVE		Asset Description: PLB A12		Total downtime: 05 hours	Warning signs before the breakdown: NO WARNING SIGNS		
Dept: Mech		Repair time: 0 hrs		Waiting time: 02 #0hrs	Sketch the working principles and the failure mode (Event which caused functional failure) Include pictures of the brackets, ?? in position		
Required by: C. Opperman				Description of fault finding and repair (what was done to fix the machine/equipment and start operations) The wheel rubber torn off.			
Part(s)/component(s) replaced: 1. Bearings 2. Wheel		Work order/Work Request: WFO 542949		Failure mode (Event which caused functional failure) Torn wheel rubber			
Why1: Max rubber torn 2. Shear forces		Why2: Shear force 1. Driven over an object 2. Driven with high speed	Why3: End of life resistance/rage was reached 1. Pushing to dock the A/C	Why4: Replacement cycle/not replaced in time 1. Operator not at the loading bridge in time.	Why5:	Counter measures: 1. Operator's procedure to be enforced 2. wheel inspections to be included in the preventive maintenance.	Category: ☒ Man ☒ Machine ☐ Method ☐ Material ☐ Environment
							Who:
							Date complete:

ORTIA ME Root Cause Analysis Sheet								
Function failure: (Which function was no longer execute) Passenger loading bridge cannot extend or retract.		Alpha 12 passenger loading bridge was not moving due to wheel puncher			Date: Monday, 20 May 2019	Time of incident: 09:30	Reported by/Operator: BMC / Lesmore	
Asset class: AIRBRIDGE - APRON DRIVE		Asset Description: PLB AL12B		Total downtime: 0220m	Warning signs before the breakdown: PLB struggles to move and is shaking forward and backwards.			
Dept: Mech		Repair time: 04 hrs		Waiting time: 0000m	Sketch the working principles and the failure mode (Event which caused functional failure)			
Required by: M. Fougere								
Description of fault finding and repair: (what was done to fix the machine/equipment and start operations) Steel wire rope was replaced, set new limits and guide bearings was adjusted.								
Part(s)/component(s) replaced: 1. Steel wire rope 2. Bearing roller adjustment				Work order/Work Request LOR 408955		Failure mode (Event which caused functional failure) Steel wire rope damaged		
Why1: Was the steel wire rope damaged Tension of cable increased	Why2: Cable Tension Tension of bearings between tunnels	Why3: Out of life expectancy/age was reached Prevent inspection to be done prior to use	Why4: Replaced cable not replaced in cycle Bearing roller adjustments	Why5:	Counter measures: 1. Operator's procedure to be enforced 2. Steel wire rope tension to be included in inspections 3. Keep spare steel wire rope in stock	Category ☒ Man ☒ Machine ☐ Method ☐ Material ☐ Environment	Who	Date complete

ORTIA ME Root Cause Analysis Sheet								
Function failure: (Which function was no longer execute) The handrail was not running/moving		Bridge had an auto level failure. Cylinder were leaking internally			Date: 09/06/2019	Time of incident: 16h30	Reported by/Operator: BMC	
Asset class: AIRBRIDGE - APRON DRIVE		Asset Description: PLB AL3		Total downtime: 2495 hours	Warning signs before the breakdown: Auto level failure			
Dept: Mech		Repair time: complete 08-10-2019		Waiting time: 1100 hrs	Sketch the working principles and the failure mode (Event which caused functional failure) Include pictures of the brackets 77 in section			
Required by: C. Opperman					 			
Description of fault finding and repair: (what was done to fix the machine/equipment and start operations) Hyd cylinders were leaking internally.								
Part(s)/component(s) replaced: Hyd cylinders repaired, flush hyd system, new hyd filter				Work order/Work Request WD 190388		Failure mode (Event which caused functional failure) Hyd cylinders leaking through		
Why1: did it lower by itself 1 internal seals were leaking through	Why2: seals collapse 1 Hydraulic seals collapse	Why3:	Why4:	Why5:	Counter measures: 1. Do more regular test on bridge cylinders	Category ☒ Man ☒ Machine ☐ Method ☐ Material ☐ Environment	Who	Date complete

ANNEX H**Estimated times for breakdowns/faults**

Diagnostic & Repair Call description	Estimated time to repair (hrs.) from the ACSA system as per Annexure H for information only
Fault by others	0.17
Power Related Fault	1
Actuator Fault	0,5
Actuator Motor	0,5
Compressor fault	1
Compressor Motor fault	0,75
Cylinders Damaged	0,75
Pipe Vessel	0,75
Beams	0,5
Water Channel Faulty	0,75
Mechanical Louvers Leaking	1
Sensors Faulty	0,5
Controller Fault	0,33
Cables fault	1
Fuse faulty	0,25
Fire System Interface Device Malfunctioning	0,5
Valve Malfunctioning	0,5
Mechanical Louvers Malfunctioning	1
Roof Vent Open and not Closing	0,25
Other unforeseen breakdown:	0,5
Other unforeseen breakdown:	0,5

Diagnostic & Repair Call description	Estimated time to repair (hrs.) from the ACSA system as per Annexure H for information only
Fault by others	0.17
Leaking	0,75
Drive Fault	0,66
Cooling Valve fault/Adjusted	0,25



Power Related Fault	1
Chiller Unit Fault	0,5
Diffuser Fault	0,4
Diffuser Dirty	1
Actuator Malfunctioning	0,25
Filters Dirty or to be Replaced	0,83
Dampers Faulty	0,5
VSD Fault	0,33
Compressor fault	1
Motor fault	0,75
Pumps Faulty	1,5
Pipes Damaged	1
Fan Faulty	0,75
Duct Damaged	1
Duct Cleaning	1
Controller Fault	0,33
V belts Damaged	0,25
Drainage System blocked	0,5
Switch Malfunctioning	0,33
Heating System Fault	0,75
Gas shurtage	2
Adjusted setpoint	0,08
Cables fault	1
Burning Smell	0,5
Fire System Interface Device Malfunctioning	0,5
Too Hot	0,25
Too Cold	0,25
No Air Flaw	0,25
Cooling Towers Fault	1
Valve Malfunctioning	0,5
Condenser fault	1
Evaporator Fault	1
Louvers Damaged	0,75
Other unforeseen breakdown:	0,5
Other unforeseen breakdown:	0,5

ANNEX I**Key Performance Indicators****1. Performance objectives**

Normal airport operational hours shall be **from 04:00 to 24:00** for every day of the year but will be confirmed/amended by the Service Manager from time to time. The Contractor must allow for sufficient after-hours work in order for scheduled work not to interfere with airport operations

Minimum Staffing Schedule

The Contractor must maintain the following **minimum** staff available at all times and should price accordingly but not limited to the listed resources:

Skill	Days per week	Hours
Administrator/Storeman	5	Mon-Fri (08:00-17:00) and whenever deemed necessary by the Employer
SITE MANAGER or SUPERVISOR	5	Mon-Fri (08:00-17:00) and whenever deemed necessary by the Employer
Mechanical Fitter	5	Mon-Fri (08:00-17:00) and whenever deemed necessary by the Employer
Refrigeration Mechanic	5	Mon-Fri (08:00-17:00) and Whenever deemed necessary by the Employer
Assistants	5	Mon-Fri (08:00-17:00) and Whenever deemed necessary by the Employer or the Artisan
Technician + Assistant	7	Mon-Sun (17:00-05:00) and Whenever deemed necessary by the Employer

* The Contractor must maintain at all times the above **minimum** staff and should price accordingly but not limited to the listed resources.

Staff compliment from 17:00 to 05:00 (Mon-Fri) and 24 hours on weekends and public holidays to be deployed, 1 technician and 1 assistant per shift.

The Contractor must have additional resources available to attend to lengthy breakdowns or breakdowns of a specialised nature.

It shall be the Contractor's responsibility to ensure that all relevant labour and safety legislation is adhered to in scheduling staff.

The Contractor shall schedule staff to complete the preventative maintenance schedule accordingly. The Tenderer must ensure that sufficient allowance for all these items is made for in his/her pricing in the Activity Schedule.


Minimum qualifications of staff for duration of contract

Item No	Key Personnel Description	Minimum Experience	Minimum Qualifications
1	SITE SUPERVISOR	Min of 2 years' experience on mechanical equipment AND 2 years supervisory Experience AND 2 years OHS experience	SAQA Accredited Trade test Refrigeration Mechanic or Fitter (Fitter & Turner) or Millwright AND OHS ¹ Training certificate
2	Mechanical Fitter	Min of 2 years' experience on maintenance or installation of pumps or motors or HVAC equipment	SAQA Accredited Trade certificate Fitter (Fitter & Turner) or Millwright
3	Refrigeration Mechanic	Min 2 years' experience in maintenance or installation of HVAC equipment	SAQA Accredited Trade certificate (Refrigeration Mechanic)
4	Assistants	Min 1 year experience on maintenance of mechanical equipment	Mechanical N2

¹ OHS means Occupational Health and Safety

2. Availability, mean time before failure and mean time to repair

The Contractor must comply with the following minimum system performance benchmarks:

*The Period of review shall be Monthly.

System Availability of Chillers and Cooling Towers	99%	IMC system captures this value
System Availability of Roof Ventilators	99%	IMC system captures this value
System Availability of AHUs and Split units	99%	IMC system captures this value
Response times during working hours	30 minutes on land side and 40 minutes on the airside	The response time is calculated from the time the contractor receives a call/misssed call/voice mail etc. from IMC and sometimes from service manager)
Response times after working hours	60 minutes on land side and on the airside	The response time is calculated from the time the contractor receives a call/misssed call/voice mail etc. from IMC and sometimes from service manager)
Closure duration during working hours	80 minutes on land side and 90 minutes on the airside	The closure duration is the time calculated from the time the contractor receives a call/misssed call/voice mail etc. from IMC and/or sometimes from service manager) until the contractor calls IMC to close the call
Closure duration after working hours	120 minutes on land side and on the airside	The closure duration is the time calculated from the time the contractor receives a call/misssed call/voice mail etc. from IMC and/or sometimes from service manager) until the contractor calls IMC to close the call
Closure of preventative maintenance work orders	All preventative maintenance work orders should be closed within 14 days of issue	All PM WO shall be closed with 6 working days from date of issuing to contractor, (Issued by ACSA either by mail or manual collection from IMC)
Closure of corrective work orders	All corrective maintenance work orders should be closed within 2 days of issue unless it is because of circumstances beyond the control of the contractor. Circumstances will have proven by contractor.	All Corrective WO shall be closed with 2 working days from date of creation by IMC, (Issued by ACSA either by mail or manual collection from IMC)



3. Emergency Response time

ACSA deems an emergency as a situation caused by unforeseen circumstance. This is only instances where:

- ❖ Delaying to source the required goods,
- ❖ Works or services will result in Loss of life or injury,
- ❖ Reputational harm,
- ❖ Financial losses,
- ❖ Legal consequences,
- ❖ Interruption of essential or
- ❖ Business services and
- ❖ Any other relevant consideration

Below are the some of the emergencies identified but not limited to the below list

Item Description	Response Time
In a case where the roof ventilator has failed	30 minutes during normal
In a case where the roof ventilator has failed	45 minutes after hours

4. Guarantees

The defect free period is defined as that period following completion of the work where no defect directly associated with the Contractors workmanship is detected.

Defect free liability period – preventative maintenance	The defect free period will be no less than the interval between preventative maintenance intervals.
Defect free liability period – corrective or breakdown maintenance	The defect free period will be no less than 90 days.
Defect free liability period – project work	The defect free period will be no less than 12 months.

There are no current (the time of this bid) warranties and guarantees on the infrastructure to be maintained by the contractor.

5. Assessments and Reviews

- Monthly assessment/review shall be done according to this NEC contract.
- Safety issues and file reviewed quarterly or as per Safety department frequency.
- Contract shall be Audited and Assessed the from time to time.
- The contractor will be assessed and scored quarterly also through the ACSA supplier development system or any other ACSA system.

6. Low service damages

Notification of Low service damages

The Service Manager will notify the contractor in writing of any Low service damages.

The Service Manager will also notify the contractor of any claims directed and incurred by ACSA as a result of the contractor failure of duties, **this will be for the account of the Contractor.**

The sources of the information shall be all reports and Audit reports which the infrastructure is subjected to (e.g. any authorised ACSA employees and any internal and external audits).

ACSA must notify the contractor in writing of its intention to claim a Low service damages within 30 days of an event or ACSA will lose its right to claim the Low service damages. Should ACSA not claim a Low service damages for an event it shall not be interpreted that the level of performance is acceptable or that ACSA shall not be entitled to claim Low service damages for similar future events. Under no circumstances shall a Low service damages be regarded as the only action ACSA may take against the Contractor or the only amount it may claim from the Contractor.

Low service damages tables

Progressive Punitive low service agreement which are entirely the contractor's fault shall be applied as below:

	Low service damages Criteria	Low service damages amount
Response time	Noncompliance with response times	R1 000,00 per event
Closure duration	Noncompliance with closure duration times	R1 000,00 per event
Closure of corrective work orders	Noncompliance with closure times for corrective maintenance work orders	R1 000,00 per event
Closure of preventative maintenance work orders	All preventative maintenance work orders should be closed within 14 days of issue	R1 000,00 per event
System Availability	Noncompliance with the system availability	R2 000,00 per system
Other Occupational Health and Safety Act 85 of 1993 which are criminal offences according to the OHS act	Termination	
There is consecutive Occupational Health and Safety Act 85 of 1993 of the same offence/class	Termination	

****Availability less than 91% for six consecutive months as measure by the IMCS system (which is the entirely the contractor's fault) will lead to contract termination.***

Not meeting system MTTR of 0.517 Hrs (i.e. MTTR > 0.517 Hrs).	R10 000/month
Not meet system MTBF 48 Hrs (i.e. MTBF > 48Hrs)	R10 000/month
Not maintaining the required minimum on-site staff requirements.	R2 000.00/position/day
Occupational health and safety act 85 of 1993 (Non-compliance with the OHS Act and its associated regulations (for example: leaving moving machinery exposed)	R2 000.00/event
Less than 100% of planned maintenance (PMs) completed per month (unless the delay in repair was agreed to by the Service Manager or his/her duly authorized representative or unless the required spares are not available to complete the work).	R4 000/month

Note work is complete after the PMs have been correctly completed returned to the contract manager and the ACSA IMC to be closed out.	
Not turning PO into completed works / completion certificate on agreed times lines as stated in Risk register	R4 000.00 / per PO / month
Other occupational health and safety act 85 of 1993 which are criminal offences according to the OHS act	Termination
3 Months Consecutive (monthly on contract period) occupational health and safety act 85 of 1993 of the same offence/class	Termination

Emergency Response time

ACSA deems an emergency as a situation caused by unforeseen circumstance. This is only instances where:

- ❖ Delaying to source the required goods,
- ❖ Works or services will result in Loss of life or injury,
- ❖ Reputational harm,
- ❖ Financial losses,
- ❖ Legal consequences,
- ❖ Interruption of essential or
- ❖ Business services and
- ❖ Any other relevant consideration

Below are the some of the emergencies identified but not limited to the below list

Item Description	Response Time	Low services damages
In a case where the roof ventilator has failed	30 minutes during normal	R1 000.00/event
In a case where the roof ventilator has failed	45 minutes after hours	R1 000.00/event

Discretionary annual contractor's performance review/assessment will be performed to consider the renewal of contract. Should the contractor's performance deemed below satisfactory the contract will not be renewed upon contract anniversary, therefore the contract will be terminated.

7. Internal and external factors

A list of some of the internal and external factors which may affect equipment SLAs / availability and are beyond the contractor's control are listed in **Annex T**. In such an event the contractor will not pay for low services damages which were caused by factors which were proven to be beyond the contractor's control.

MAINTENANCE RECORD SHEETS

When maintenance is performed, record sheets must be completed and signed off by both the Technician and an ACSA representative.

These record sheets must be stored for the duration of the contract and should be available for inspection at any time. **The lack of complete history files will result in immediate cancellation of the contract.**

All record sheets, job cards, history reports etc. will stay the property of ACSA and should be available on request. At the end of the contract period a complete set of documentation must be handed over to ACSA.



The contractor shall further provide copies of these record sheets to the ACSA contract manager by the fifth day of every month. **No money will be paid out if record sheets are not handed in.**

ANNEX J

**OCCUPATIONAL HEALTH AND SAFETY AGREEMENT
IN TERMS OF SECTION 37(2) OF THE OCCUPATIONAL HEALTH & SAFETY ACT (ACT 85 OF
1993) & CONSTRUCTION REGULATION 5.1(k)**

This form is in C1.3 in this contract and must be filled in by the contractor

**ANNEX K****Minimum Maintenance Programme**

The Tenderer shall include a suggested maintenance programme that must attempt to cover all requirements under this contract. The below list should be used as a minimum. The responsibility lies with the contractor in ensuring compliance to OEM instructions

HVAC Mechanical, Electricals and controls system

Electrical COC for all points of Control to points of consumption	After Installation and modification
Electrical and Control panel wiring drawings	Yearly (Y)
Fire Damper relay test report	Quarterly (Q)
AHU Fire signal relay test records	Quarterly (Q)
Smoke extraction and fresh air fan test records (under fire condition)	Quarterly (Q)
Plant Room refrigerant leak detector test records (SANS 10147)	Quarterly (Q)
Maintenance records as per procedure	Monthly/Quarterly//Yearly
DB Earth leakage test records	Quarterly (Q)

All Maintenance of HVAC Mechanical Systems shall be scheduled, at least at minimum , to the requirements of the following tables:

Table 1: Building management System

Infrastructure description	Frequency	Description of the works
BMS	Daily	Check that the BMS is working
	Monthly	Check that all sensors linked to the BMS are working and replace where necessary
	Monthly	Check that the chiller and cooling tower rotation/sequencing is working and adjust where necessary.
	Monthly	Check that all HVAC equipment go into sleep mode and activates at set times.
	Monthly	Check and adjust settings where necessary

Table 2: Energy Management System

Infrastructure description	Frequency	Description of the works
EMS (Energy Management System) DOMTEX and KB2	Daily	Check that the energy management is functioning according to design (Chiller sequencing, operation and control).
	Weekly	Download and provide a chiller energy consumption report.
	Monthly	Check that all sensors linked to the EMS are working and replace where necessary
	2 Monthly	Check that the UPS is working and service
	Monthly	Check and adjust settings where necessary

Table 3: All motor pumps

Infrastructure description	Qty	Frequency	Description of the works
General booster pumps and Chiller primary and condenser pumps.	44 pumps (@Cargo, International and Domestic)	Daily	Check that the motor AMPS and Voltage are within range
		Daily	Check that the motor cooling fans are functioning according to specification.
		Quarterly	Test and Service (Disassembly and assembly) the VSDs and adjust settings where necessary
		Monthly	Check all flow meters including healthy status on the BMS and replace where necessary.
		Monthly	Check all Temperature transmitters and healthy status on the BMS.
		Monthly	Check all pressure gauges and replace where necessary
		Monthly	Check all the temperature gauges/sensors and replace where necessary
		Monthly	Check that the pressure transmitters are functioning according to specification and healthy status on the BMS.

Table 4: Air Handling Units

Infrastructure description	Qty	Frequency	Description of the works
Air handling units	426 units (Domestic, International and CTB)	Weekly	Check that the FAN motor and heater banks' AMPS and Voltage are within range.
		Weekly	Check that the Volt meters and Ammeters are functioning according to specification and replace where necessary.
		Monthly	Test all the emergency stops
		Monthly	Test all heaters for functionality and a healthy link status with the BMS
		Monthly	Check and test the pilot lights (Fan and heater bank status lights)
		Monthly	Check and test all switches and replace where necessary
		Monthly	Check and test the fire detection signal relay and record results thereof
		Monthly	Check and test all flow switches and replace where necessary
		Quarterly	Test and Service (Disassembly and assembly) the VSDs and adjust settings where necessary
		Monthly	Check and test that all three-way and two-way valve actuators are functioning within specification.
		Monthly	Check and test all Temperature sensors and transmitters and healthy status on the BMS.
		Monthly	Check all pressure gauges and replace where necessary
		Monthly	Check all the temperature gauges and replace where necessary
		Quarterly	Check and test all controllers according to operating philosophy and adjust settings/ re-program where necessary

Table 5: Cooling towers

Infrastructure description	Qty	Frequency	Description of the works
Cooling towers	12 units (Domestic, International and Cargo)	Weekly	Check that the FAN motors' AMPS and Voltage are within range.
		Weekly	Test and Service (Disassembly and assembly) the VSDs and adjust settings where necessary
		Monthly	Test all the emergency stops
		Monthly	Check and test all Temperature sensors and transmitters and healthy status on the BMS.
		Monthly	Check all cooling tower ultrasonic level meters and repair/replace where necessary
		Monthly	Check all solenoid valves and replace where necessary.
		Monthly	Test all actuators and repair/replace where necessary.
		Monthly	Check all pressure gauges and replace where necessary
		Monthly	Check all pressure transmitters and replace where necessary.
		Monthly	Check all the thermometers replace where necessary

Table 6: Chillers

Infrastructure description	Qty	Frequency	Description of the works
Chillers	13 units (Domestic, International and Cargo)	Weekly	Check the compressor amps and voltage, and take chiller energy meter readings
		Weekly	Check the chiller settings and adjust where necessary
		Monthly	Check that the chiller sensors are working and replace where necessary.
		Monthly	Check that the wiring in the chiller panel is as per regulations and adjust where necessary.
		Weekly	Check all circuit breakers and replace where necessary
		Weekly	Check all lugs and replace where necessary

Table 7: Electrical Panels and DB's

Infrastructure description	Qty	Frequency	Description of the works
Panels and DBs	428 + units (Domestic, International, CTB, Remote sites and Cargo)	Weekly	Check HVAC plant room lighting and replace where necessary with LED lights.
		Yearly	Label/Update all HVAC Plant Room Panels and DBs
		Monthly	Compile/update panels and DB register
		Semi-annually	Compile/update panel and DB drawing register.
		Semi-annually	Verify panel and DB drawings and amend where necessary
		Monthly	Check that all door panels are lockable and repair/replace where necessary
		Monthly	Inspection and testing of panels components in line with SANS 10142.
		Monthly	Remove dust and other deposits
		quarterly	Painting of DB's when it is necessary
		Monthly	Check voltmeters and ammeters and replace where necessary
		Monthly	Check for loose connections and tighten circuit breaker terminals.
		quarterly	Check cable insulation and replace where necessary.
		quarterly	Manually switch the circuit breakers on and off.
		quarterly	Check and replace panel lights where necessary
		quarterly	Check isolator switches and replace where necessary
		Quarterly	Check the fire detection interfacing relays where applicable and replace where necessary.
		Monthly	Check all circuit breakers, test Earth leakages etc and replace where necessary.
		Yearly	Perform COCs on all HVAC Plant room panels and DBs when installation is extended or modified.

Table 8: Diffusers and Wall Thermostats

Infrastructure description	Qty	Frequency	Description of the works
VAV Diffusers and wall thermostats	2000 + units (Domestic, International, CTB, Remote sites and Cargo)	Monthly	Test VAV diffusers and connection to the unit controllers
		Semi-annually	Test wall thermostats and replace where necessary
		Monthly	Ensure VAV diffuser heating elements are connected to the occupants' billable power supply.

Table 9: Fans

Infrastructure description	Qty	Frequency	Description of the works
Smoke Extraction fans, toilet extraction fans and fresh air induction fans	1000+ units (Domestic, International, CTB, Remote sites and Cargo)	Monthly	Check the toilet extraction and fresh air induction fans amps and voltage
		Quarterly	Label all fans with a supply DB/panel details
		Quarterly	Test all smoke extraction fans and interfacing with the fire detection system.
		Monthly	Compile/update fans register. The register should contain the model, make, power rating, voltage, rated amps and flow rate.
		Monthly	Check if CO monitors at basement parking are working
		Monthly	Test that the parking extraction fans extract as soon as the CO level is 50ppm
		Monthly	Test if the parking fresh air fans supply fresh air as triggered by the CO monitors
		Monthly	Test if fresh air fans switch off as soon as the fire detector in the zone is activated
		Monthly	Check if the fresh air fans are delivering the right volume of fresh air

Table 10: Spares management

Infrastructure description	Qty	Frequency	Description of the works
Spares Management	1000+ items (Domestic, International, CTB, Remote)	Monthly	Compile/update an inventory list and allocation of stock codes
		Daily	Administer a web-based cloud inventory management system
		Daily	Barcoding and scanning incoming and outgoing stock items



	sites and Cargo)	Monthly	Maintain shelving, floors and access control in the store room
		Monthly	Management of rotatable inventory management system
		Monthly	Stock counting and compiling reports as per ACSA Inventory Management system
		Quarterly	Stock counting and compiling reports as per ACSA Inventory Management system

All Preventative Maintenance Activities but not limited to:

Roof ventilators

Independent Registered Engineer Roof vents, Fire Dampers, Smoke/Toilet Extraction and Fresh air fans Test Report (Insurance Purposes)	Yearly (Y)
Roof vents test records	Monthly (M)
Fresh air fans test records	Monthly (M)
Maintenance records (As Per Procedure)	Monthly/6 Monthly/Yearly
Fire dampers test records	Monthly (M)

Infrastructure	Maintenance Activities	Frequency
Ventilator	Check and adjust cable controls	Quarterly
Ventilator	Check spring tensioners on units	Quarterly
Ventilator	Check fusible plates and link pins	Quarterly
Ventilator	Check all pulleys, swivel blocks and capstans for correct operation	Quarterly
Ventilator	Check all cable controls	Quarterly
Ventilator	Ensure that all cables are not fouled in any way	Quarterly
Ventilator	Check condition of all side vents, weights, springs and hinges	Quarterly
Ventilator	Ensure that all vents are opening, closing and sealing properly	Quarterly
Ventilator	Ensure that all bird screens are not damaged and that they fit securely	Quarterly
Ventilator	Clean Ventilators	Quarterly
Ventilator	Check waterproofing of all flashings and joints	Quarterly
Control Panel	Check for flawless operation	Quarterly
Control Panel	Inspect batteries	Quarterly
Compressor	Check operations of compressors	Quarterly
Compressor	Check proper operation of all compressors	Quarterly
Compressor	Ensure that all water is drained out of all compressors	Quarterly
Compressor	Ensure that all compressor test certificates are updated and current	Quarterly

The Contractor are to ensure that the proposed maintenance programme agrees with the OEM maintenance recommendations.

Annual Major Maintenance:

Infrastructure	Maintenance Activity	Frequency
Ventilator	Clean Ventilator and rain channel	Annually
Ventilator	Clear obstacles and debris from working parts	Annually
Ventilator	Replace all defective fusible links where required	Annually
Ventilator	Replace all defective cables and springs where required	Annually
Ventilator	Waterproof all flashings and joints where required	Annually
Control Panel	Repair all electrical wiring that does not operated correctly	Annually
Control Panel	Repair all control panels that do not operate correctly	Annually
Control Panel	Replace all control panel back-up batteries that do not operate correctly	Annually
Ventilator	Replace all defective safety pins	Annually
Ventilator	Replace all defective actuators	Annually
Compressor	Rectify leaks in pneumatic systems	Annually
Compressor	Full service on compressor systems	Annually



Compressor	Ensure that all compressor test certificates are updated and current	Monthly
------------	--	---------

The yearly Pressure Vessel Testing, as per the OHS Act to be conducted once-off in this contract.

ANNEX L (Contractor to fill in)

ACSA SERVICE & MAINTENANCE CONTRACTORS
ENVIRONMENTAL TERMS AND CONDITIONS TO COMMENCE WORK - EMS 048

The following Environmental Terms and Conditions shall be strictly adhered to by all contractors when conducting works for the Employer. The Employer shall audit Contractor activities, products and services on an ad hoc basis to ensure compliance to these environmental conditions. Any pollution clean-up costs shall be borne by the Contractor.

ISSUE	REQUIREMENT
Environmental Policy	ACSA's (the Employer's) Environmental Policy shall be communicated, comprehended and implemented by all appointed Contractor staff.
Storm water, Soil and Groundwater Pollution	- No solid or liquid material may be permitted to contaminate or potentially contaminate storm water, soil or groundwater resources. - Any pollution that risks contamination of these resources must be cleaned-up immediately. Spills must be reported to the Employer immediately. Contractors shall supply their own suitable clean-up materials where required. - Washing, maintenance and refuelling of equipment shall only be allowed in designated service areas on the Employer property. It is the Contractor's responsibility to determine the location of these areas. - No leaking equipment or vehicles shall be permitted on the airport.
Air Pollution	- Dust: Dust resulting from work activities that could cause a nuisance to employees or the public shall be kept to a minimum. - Odours and emissions: All practical measures shall be taken to reduce unpleasant odours and emissions generated from work related activities. - Fires: No open fires shall be permitted on site.
Noise Pollution	- All reasonable measures shall be taken to minimize noise generated on site due to work operations. - The Contractor shall comply with the applicable regulations regarding noise.
Waste Management	- Waste shall be separated as general or hazardous waste. - General and hazardous waste shall be disposed of appropriately at a permitted landfill site should recycling or re-use of waste not be feasible. - Under no circumstances shall solid or liquid waste be dumped, buried or burnt. - Contractors shall maintain a tidy, litter free environment always in their work area. - Contractors must keep on file: - The name of the contracting waste company - Waste disposal site used - Monthly reports on quantities – separated into general, hazardous and recycled - Maintained file of all Waste Manifest Documents and Certificates of

	Safe Disposal 5. Copy of waste permit for disposal site This information must be available during audits and inspections.
Handling & Storage of Hazardous Chemical Substances (HCS)	• All HCS shall be clearly labelled, stored and handled in accordance to Materials Safety Data Sheets. • Materials Safety Data Sheets shall be stored with all HCS. • All spillages of HCS must be cleaned-up immediately and disposed of as hazardous waste. (HCS spillages must be reported to the Employer immediately). • All contractors shall be adequately informed with regards to the handling and storage of hazardous substances. • Contractors shall comply with all relevant national, regional and local legislation regarding the transport, storage, use and disposal of hazardous substances.
Water and Energy Consumption	the Employer promotes the conservation of water and energy resources. The Contractor shall identify and manage those work activities that may result in water and energy wastage.
Training & Awareness	The conditions outlined in this permit shall be communicated to all contractors and their employees prior to commencing works at the airport.

Low Service Damages

Low service damages shall be imposed by the Employer on Contractors who are found to be infringing these requirements and/or legislation. The Contractor shall be advised in writing of the nature of the infringement and the amount of the low service damages to be imposed. The Contractor shall take the necessary steps (e.g. training/remediation) to prevent a recurrence of the infringement and shall advise the Employer accordingly. The Contractor is also advised that the imposition of low service damages does not replace any legal proceedings the Council, authorities, landowners and/or members of the public may institute against the Contractor.

Low service damages shall be between R 200.00 and R 20,000.00, depending upon the severity of the infringement. The decision on how much low service damages to impose will be made by ACSA's (the Employer) Airport Environmental Management Representative in consultation with the Airport Manager or his/her designate and will be final. In addition to the low service damages, the Contractor shall be required to make good any damage caused due to the infringement at his/her own expense.

I, _____ (name & surname) of _____

_____ (company) agree to the above conditions and acknowledge the Employer's right to impose low service damages should I or any of my employees or sub-contractors fail to comply with these conditions.

Signed: _____ on this date: _____ (dd/mm/yyyy)



at: _____ (airport name).



ANNEX M

Maintenance of Roof ventilators and HVAC Mechanical Systems Spares List

STOCK COUNT

Name of Storer Room: KB2 AND KB2A Room Location: KB2 Name of Contractor:	Date of Stock Count: 31 Month of Stock Count: JANUARY 2022
---	---

Stock Count Sheet

Name of Work Coordinator Name of Stock Coordinator 	Signature of Work Coordinator Signature of Stock Coordinator
---	---

Spare Part Code	Bin Location	Spare Part Description	FROM	Min Qty	Qty on KARD EX	Qty Counted	Qty Damaged/ Obsolete	Qty Shortfall	Qty Excess	Unit Price	Stock Value
BE-48-48		AC Ammeter - BE 48-BEW-48mm AC 1 A AC	each	0	0	0	No			R -	R -
BE-48 500 VAC		AC Ammeter - BE 48-BEW-48mm AC 500 VAC	each	0	0	0	No			R -	R -

BE - 48 400 VAC		AC volmeter - BE 48 - BEW - 72mm AC 400 VAC	e a c h	0	0	0	No			R -	R -
BE - 96-60 VAC		AC Ammeter - BE 96 BEW - 96mm AC 60 VAC	e a c h	0	0	0	No			R -	R -
BE - 96- 400v		AC Voltmeter - BE -96 - BEW -400V	e a c h	0	0	0	No			R -	R -
SQ72- 40AD	A2	Ammeter 40A AC direct connected	e a c h	10	8	8				R 228,0 0	R 1 824,00
BM001 37	II	1,5mm red insulated lug 8mm	p a c k	10	300	30 0				R 75,00	R 22 500,00
BM001 32	II	1,5mm red insulated lug 6mm fork	p a c k	10	200	10 0				R 58,00	R 5 800,00
BM002 26	II	2,5mm blue insulated lug 5mm fork	p a c k	10	100	10 0				R 56,00	R 5 600,00
BM003 20	II	4,6mm yellow insulated lug 4mm	p a c k	10	0	0				R 68,00	R -
BM001 26	II	1,5mm red insulated lug 5mm fork	p a c k	10	200	20 0				R 52,00	R 10 400,00
BM002 32	II	2,5mm blue insulated lug 6mm fork	p a c k	10	100	0				R 66,00	R -
BM002 20	II	2,5mm blue insulated lug 4mm fork	p a c k	10	0	0				R 49,00	R -
BM003 31	II	4,6mm yellow insulated lug ring/100	p a c k	10	100	20 0				R 68,00	R 13 600,00
BM002 51	II	2,5mm blue insulation lug 100m	p a c k	10	0	0				R 57,00	R -
BM001 60	II	1,5mm red insulation ferrule	p a c k	10	0	0				R 71,00	R -
BM003 26	II	4,6mm yellow insulated lug 5mm fork	p a c k	10	0	0				R 62,00	R -
BM003 19	II	4,6mm yellow insulated lug 4mm	p a c k	10	200	20 0				R 105,0 0	R 21 000,00
BM003 32	II	4,6mm yellow insulated lug 6mm fork	p a c k	10	20	0				R 62,00	R -

BM00237	II	2,5mm blue insulated lug 8mm	pack	10	200	200				R 96,00	R 19 200,00
BM00151	II	1,5mm red insulated lug 100m	pack	10	0	0				R 51,00	R -
BM00251	II	2,5mm blue insulated lug 100m	pack	10	100	0				R 57,00	R -
BM00337	II	4,6mm yellow insulated lug 8mm	pack	10	100	100				R 92,00	R 9 200,00
BM00108	II	1,5mm red insulated lug 3mm fork	pack	10	0	0				R 43,00	R -
BM00231	II	2,5mm blue insulated lug 6mm	pack	10	200	200				R 81,00	R 16 200,00
BM00119	II	1,5mm red insulated lug 4mm	pack	10	100	100				R 43,00	R 4 300,00
BM00131	II	1,5mm red insulated lug 6mm	pack	10	100	100				R 78,00	R 7 800,00
CONT/0100/00250	2E	Controllers	each	5	0	0				R 728,00	R -
BM00219	II	2,5mm blue insulated lug 4mm	pack	10	200	200				R 49,00	R 9 800,00
PTAVA VI19801	2E	Bayonet type diffuser	each	20	0	0				R 1 647,00	R -
BM00137	II	1,5mm red insulated lug 8mm ring	pack	10	0	0				R 75,00	R -
BM00109	II	1,5mm red insulated lug 3mm	pack	10	100	100				R 41,00	R 4 100,00
NR24A-SR	B7	Std actuator 10Nm 24V MOD	each	16	11	11				R 2 204,10	R 24 245,10
B2502	2C	25x4 core cable	metres	65	0	0				R 1 000,00	R -
6012,02	B11	M10H eu2 telux switch	each	3	0	0				R 828,92	R -
BUY00002	B5	Micro830 controller	each	5	5	5				R 12	R 60 437,50

			ch						087,50	
930-83222534	B3	Diff press switch 50-500Pa	each	4	2	2			R 304,00	R 608,00
CRH0005	B17	24000BTU compressor	each	1	1	1			R 1 622,00	R 1 622,00
GGR0220	B15	R22 disposacan 13,6kg	each	1	1	1			R 760,00	R 760,00
EGC0020	B13	Run capacitor 50uF 450V	each	1	1	1			R 94,00	R 94,00
2517X42MM	B19	2517X42MM taper lock bush	each	2	0	0			R 166,88	R -
VB16N X1700 F	2D	SPB 1700 fenner wedge belt	each	3	0	0			R 106,57	R -
125A3P	EE	125A isolator	each	1	1	1				R -
125X2 SPB	A18	125X2 SPB T/L pulley 2012-50	each	2	1	1			R 274,96	R 274,96
150X2 SPB	A18	150X 2 SPB T/L pulley 2012-50	each	2	1	1			R 752,22	R 752,22
160X3 5P8	B18	160X 3 SPB T/L Pulley 2517-65	each	2	2	2			R 512,16	R 1 024,32
TB/T1-S	B19	Duct temp	each	15	15	15			R 417,00	R 6 255,00
IQ4/NC /00/230	B19	Controller	each	1	1	1			R 9 386,00	R 9 386,00
IQ4E/16/BAC/230	B19	Controller	each	14	1	1			R 17 419,00	R 17 419,00

EML19 43033	2H	3kw 4P 380 motor	e a c h	1	0	0			R 2 316,6 2	R -
EML32 03033	2H	15KW 4P 380 motor	e a c h	2	1	1				R -
BE-96- 600v		AC Voltmeter - BE -96 - BEW -600V	e a c h	0	0	0	No		R -	R -
20-200		AIR Flow Switch	e a c h	0	0	0	No		R -	R -
F61SB -9100		Airflow switch - F61SB -9100 - Johnson controls - 15.6u.s.gal / min	e a c h	0	0	0	No		R -	R -
P233A- 4		Air pressure switch - P233A-4 - Johnson controls - 5 (2) A 250 V	e a c h	0	0	0	No		R -	R -
SANS1 50- 1000		Alvern cable - SANS150-1000V	e a c h	0	0	0	No		R -	R -
VA- 7820- GGA- 11		Actuator-7820-GGA- 11-atbro systems	e a c h	0	0	0	No		R -	R -
VA- 71025		Actuators - VA - 71025 - Johnson controls - 24V-50/60Hz.4.7 VA	e a c h	0	0	0	No		R -	R -
HA022 30010	B1 4	Super F steel cut disc 230mm	e a c h	10	9	9			R 47,00	R 423,00
HA021 15035	B1 4	Super F steelgrind disc 115x6,4	e a c h	20	17	17			R 40,00	R 680,00
HA021 15041	B1 4	Super F 2in1 counter box 115	e a c h	4	0	0			R 109,4 1	R -
GRAE- 40- NPP		Ball Bearing - GRAE 40 - NPP - B - INA - H1031-15	e a c h	0	0	0	No		R -	R -
STOE0 1310	B2	PC board -mitsubishi	e a	1	1	1			R 2	R 2 950,00

			ch						950,00	
TE200 A20	B4	Space micro sensor 20k	each	30	30	30			R 245,00	R 7 350,00
003563 7	B1 0	Omron timer	each	20	15	15			R 1 052,00	R 15 780,00
GX16- 53U	A2 9	3P on-off-on changeover switch	each	50	43	43			R 376,64	R 16 195,52
GRB- 1003	A4	Crabtree 1L 1W switch complete	each	10	4	4			R 29,86	R 119,44
GW92 111	A2 2	1P 32A circuit breaker	each	20	5	5			R 70,00	R 350,00
20- 1602- 01	B9	Panel lock 8mm sq key	each	200	190	190			R 117,00	R 22 230,00
017025 9368	2I	45kw speed drive	each	2	2	2			R 52 142,40	R 104 284,80
SACF W10	2I	VSD 11kW 380v 24A	each	2	1	1			R 8 917,00	R 8 917,00
999908 015	2J	QD red oxide primer 5L	each	1	1	1			R 195,00	R 195,00
999902 329	2J	QD enamel black gloss 1Lt	each	2	2	2			R 75,00	R 150,00
316514 014940	B1 4	Cutting disk 115x2,5mm steel	each	10	10	10			R 13,11	R 131,10
999901 020	B1 4	Rivets fap 4012 pkt 100	packet	1	1	1			R 27,00	R 27,00
600572 101879	B1 4	Drillbit HSS IND 4,0mm card	each	4	4	4			R 20,00	R 80,00

999902 847	B1 4	Drilbit SDS+16x20	e a c h	5	2	2				R 78,00	R 156,00
999916 394	B1 4	Rawbolt M10 import	p a c k e t	1	1	1				R 9,50	R 9,50
2670	A1	Isolator switch 4x2 30A D/pole	e a c h	10	6	6				R 132,3 0	R 793,80
2445/1 01P	A1	Cover plate 4x2 steel white	e a c h	10	6	6				R 16,80	R 100,80
AR- A05- 14A	C4	Perf . Cable tray	e a c h	2	2	2				R 207,0 0	R 414,00
6896H	A4	Ct horiz single 16A SSO 4x2	e a c h	10	8	8				R 73,50	R 588,00
6546H	A4	Ct horiz sso coverplate 4x2	e a c h	10	8	8				R 14,70	R 117,60
E14W BC840 CW	A1 3	Lamp flou elec saver 14w	e a c h	40	36	36				R 19,95	R 718,20
Y60PB H	B8	Bulkhead fit 60W- 100W PVC BC	e a c h	40	40	38				R 39,95	R 1 518,10
T2M 230VA C	A3 0	Multi range /mins range 230vac	e a c h	40	25	25				R 513,6 0	R 12 840,00
620222 C3		Ball Bearing - 620222C3 - NSK - WD11/38x14x38	e a c h	0	0	0	No			R -	R -
6-294		Bo- cutter Hammer - 6- 294-E.T.N. - 80mm, 90kw	e a c h	0	0	0	No			R -	R -
6-288		Bo - cutter hammer - ETN - 180mm, 110kw	e a c h	0	0	0	No			R -	R -
LZ -T - 100VA 230/2		Bo Transformer -LZ -T -100VA230/2	e a	0	0	0	No			R -	R -

			c h							
6	B1 4	M6 nuts	e a c h	50	50	50			R 0,10	R 5,00
8	B1 4	M6 x40mm bolts	e a c h	50	50	50			R 0,75	R 37,50
3M- 74717	Q	Blue general purpose pvc elec tape 0,18mm	e a c h	10	1	1			R 30,00	R 30,00
3M- 74714	Q	Red general pvc elec tape 0,18mm thick	e a c h	10	0	0			R 30,00	R -
3M- 74715	Q	White general purpose pvc elec tape 0,18mm	e a c h	10	0	0			R 30,00	R -
3M- 74712	Q	Black general purpose pvc elec tape 0,18mm	e a c h	10	0	0			R 30,00	R -
60w- 100w		Bulkhead fit 60w-100w Pcv Bc/y60pbh	e a c h	0	0	0	No		R -	R -
XOXG/ 20X12 5		Bolts and Nuts	e a c h	0	0	0	No		R -	R -
MRCA P440V 16		CAP MOT RUN 16MF 450V TERM/STD	e a c h	0	0	0	No		R -	R -
MRCA P440V 50		CAP MOT RUN 40MF 450V TERM/STD	e a c h	0	0	0	No		R -	R -
M4/6	L	4mm terminal	e a c h	10 0	60	60			R 10,90	R 654,00
M10/10	L	10mm terminal	e a c h	10 0	0	0			R 24,60	R -
M6/8	L	6mm terminal	e a c h	10 0	43	43			R 18,50	R 795,50

UK10N	L	Phoenix 10mm terminal	each	100	40	40				R 23,88	R 955,20
MA2,5/5	L	2,5mm terminal	each	100	70	70				R 10,90	R 763,00
MRCA P444V 60		CAP MOT RUN 60MF 450V TERM/STD	each	0	0	0	No			R -	R -
1/2"x3.0"		C fan motor - 5 KCP39PGR8325 - Genteg - 4.5A 220V	each	0	0	0	No			R -	R -
AMY-2 180s 230V	E	Maniature timer 230vac 180s	each	10	1	1				R 217,00	R 217,00
A7401	A3	16A switched socket outlet 4x4 c/white	each	10	4	4				R 63,00	R 252,00
PTK20 305	2J	Plascon 2k fast hardner	each	10	2	2				R 594,00	R 1 188,00
M35/16	I	35mm terminal	each	20	0	0					R -
f		Circuit Breaker - NF101A - Hager - 230/400V-50/60Hz1A	each	0	0	0	No			R -	R -
MC021 005	2J	2K orange	each	20	8	8				R 1 127,00	R 9 016,00
2601P 0120	2J	Rhynolox white line roll 70x50m P120	each	10	5	5				R 190,00	R 950,00
PAP00 2	2J	Paper masking brown	meters	100	0	0				R 13,00	R -
PAP00 1	2J	Paper masking white	meters	100	33	33				R 11,50	R 379,50
EURO CEL4	2J	Eurocel masking tape blue	each	100	47	47				R 6,13	R 288,11

			ch							
APU00 107000 5A1	2J	Plascon Etch primer	each	10	2	2			R 719,00	R 1 438,00
A9F64 320	A1 2	Schneider 20A circuit breaker	each	40	8	8			R 709,22	R 5 673,76
A9F64 132	A	Schneider 32A 1P MCB 5KA	each	10	1	1			R 159,63	R 159,63
A9f641 06		Circuit Breaker - NF106A - Hager - 230/400V-50/60Hz1A	each	0	0	0	No		R -	R -
A9f643 63	B	Circuit Breaker - A9f64163 63 AMP	each	10	0	0	No		R 759,84	R -
A9f643 40	A	40 AMP circuit breaker	each	10	0	0	No		R 747,08	R -
A9f641 50	R	Circuit Breaker - A9f64120 50 AMP	each	10	0	0	No		R 177,82	R -
LPJ- 15SP	A2 0	600V 15AMP class j fuse	each	5	4	4			R 55,60	R 222,40
NF20A		Circuit Breaker - NF20A - Hanger - 230/415V-50/60Hz	each	0	0	0	No		R 525,80	R -
000308 200011	2J	Lacquer thinner GR 5L	litres	50	40	40			R 125,00	R 5 000,00
LAM- 1022	B1	Flour 2ft 18W osram	each	100	92	92			R 9,11	R 838,12
FLEX1, 5R	SS	Flexible wire 1,5mm red	metres	100	0	0			R 282,10	R -
LC1D2 5M7	A1 1	Tele cont 25A 230VAC	each	30	0	0			R 1 263,59	R -
LC1E5 0U5	G	Schneider contactor 3P 50A TVS	each	10	2	2			R 1	R 2 981,98

			ch						490,99	
LC1D3 2P7	A1 0	D contactor 32A 1NO+1NC 220VC01	each	6	0	0			R 2 068,68	R -
LC1D1 8M7	A1 0	Tele cont 18A 220VAC contactor	each	20	1	1			R 904,79	R 904,79
LC1E3 210U5	H	Schneider contactor 3P 32A TVS 1NO15	each	10	0	0			R 876,99	R -
L/9692 36	C	125A breaker	each	2	1	1			R 805,87	R 805,87
L/9692 57	N	Lrd340Thermal overload	each	5	0	0			R 1 689,79	R -
LC1D4 0	JJ	40A 3P contactor	each	5	0	0			R 2 842,11	R -
LC1D9 5P7	A1 1	95A contactor	each	5	2	2			R 6 895,61	R 13 791,22
LADN1 1	K	Aux contact	each	10	7	7			R 257,41	R 1 801,87
LC1E4 0U5	H	Schneider contactor 3P 40A TVS 18,5KW	each	10	3	4			R 1 207,99	R 4 831,96
LA DANG ER 1	S	Danger labels 120x120mm	each	200	150	150			R 2,20	R 330,00
LC1DP 40AP7	T	Contactor 40A 220VAC	each	10	1	1			R 2 439,99	R 2 439,99
LB MAIN SWITC H	S	Red on white switch label	each	200	150	150			R 1,00	R 150,00
LC1E4 0M5	T	Schneider contactor 3P 40A TVS 18,5KW	each	10	0	0			R 1 207,99	R -

E1010 RD	II	Insul bootlace red 1,0mm	p a c k	5	100	100				R 0,51	R 51,00
E1008-500	II	1mm red bootlace ferrules/500	p a c k	3	3	3				R 64,00	R 192,00
1S4A	II	Insul lug red 4mm spade	p a c k	5	100	100				R 0,97	R 97,00
E1510 BK	II	Insul bootlace black 1,5mm	p a c k	5	100	100				R 0,52	R 52,00
1P10	II	Insul lug red pin	p a c k	5	100	100				R 0,86	R 86,00
1FB10	II	Insul lug red flat blade	p a c k	5	100	0				R 1,54	R -
10111 PB	A2 1	Padlockable handle	e a c h	10	7	7				R 294,10	R 2 058,70
9023 SMA		CLamp terminal socket - 90.23.SMA - finder - 10A -250V	e a c h	0	0	0				R -	R -
20MM SABS	2A	PVC 20mm sabs conduit pipes	e a c h	10	6	6				R 7,96	R 47,76
13002	A1 6	Fuse 500V 2A	e a c h	20	28	28				R 8,00	R 224,00
13016	A1 6	Fuse 500V 16A	e a c h	20	20	20				R 8,00	R 160,00
13006	A1 6	Fuse 500V 6A	e a c h	20	9	9				R 8,00	R 72,00
13010	A1 6	Fuse 500V 10A	e a c h	20	20	20				R 8,00	R 160,00
13001	A1 6	Fuse 500V 1A	e a c h	20	20	20				R 8,00	R 160,00
003240 8	A2	LX1-FP p 230v 50HZ coil	e a c h	10	0	0				R 821,00	R -

152202	F	PVC shroud no 2	each	10	0	0				R 5,30	R -
152203	F	PVC shroud no 3	each	10	2	2				R 7,70	R 15,40
140024 896	A1 3	Oppl cfl 11w E27(light bulb)	each	10 0	0	0				R 13,50	R -
6x55	F	Nail in anchor	each	50 0	0	0				R 0,66	R -
003240 7	A2	LC1-FDP150A contactor 3phase	each	10	0	0				R 3 101,0 0	R -
0220H 100	2I	22KW (30HP,3 phase ,380-480VAC	each	2	0	0				R 14 323,8 8	R -
0550H 100- 4COF N	2I	55KW 3 phase 38-480VAC ,with LCD	each	2	1	1				R 26 341,1 5	R 26 341,15
0330H 100- 4COF N	2I	30KW (40HP) 3 phase, 380-480VAC	each	2	0	0				R 17 055,8 4	R -
0185H 100- 4COF N	2I	18,5KW (25HD),3 phase ,380-480VAC	each	2	0	0				R 11 366,5 0	R -
999	2I	22KW (30HP)3 phase	each	2	0	0				R 14 323,8 8	R -
PGD10 00W00	A2 4	Wall mount graphic display	each	5	2	2				R 3 048,1 0	R 6 096,20
0015H 100- 4COF N	2I	1,5KW 3 phase 380-480V AC	each	2	2	2				R 5 238,6 2	R 10 477,24
JTN60 030	A2 0	JTN Fuse 0-30a	each	5	5	5				R 210,0 0	R 1 050,00
LC1D0 9P7		D.COUNT.9A.AC3.1N O	each	0	0	0	No			R -	R -

			ch							
LC1D1 8P7		D.COUNT.18A.AC3.1N O+NC.220VCOIL	each	0	0	0	No		R -	R -
RL10X 6	II	Non insulated ring/lug 10x6mm/100	pack	10	0	0			R 181,0 0	R -
RF505 B3	B1 3	Danfoss suct drier DAS 5/8"	each	1	1	1			R 316,4 0	R 316,40
LRD22	M	Tele o/l relay 16-24A	each	10	0	0			R 982,7 9	R -
LRD10	M	Relay 4-6A	each	5	1	1	No		R -	R -
PLX AU 120		Contact Block support AU 120	each	0	0	0	No		R -	R -
LPX C10		Contact Block /LPX C10-Green N/O	each	0	0	0	No		R -	R -
LPX C01		Contact Block/LPX C01-Red N/C	each	0	0	0	No		R -	R -
654/10 1		Cover Lever 4x2 1 Way White	each	0	0	0	No		R -	R -
140024 896	A1 4	Osr 11watts (60W) B22 cd cool white	each	10 0	50	50			R 19,38	R 969,00
DINIM SLOT	2G	Din rail 1M slotted mild steel	each	10	0	0			R 32,67	R -
MCE D2510- m	G	Contactor 25A	each	10	1	1				R -
DT- 200VD C/12	A1	230/12VDC 16A DIN power supply	each	5	0	0			R 1 316,0 0	R -

DDP2 120m 230VA C	X	Delay off timer 2c/0	e a c h	50	18	19				R 327,0 0	R 6 213,00
12V AC 3		1SRM	e a c h	0	0	0	No			R -	R -
NB3- 63	KK	63A 3P 4,5KA c curve din mcb	e a c h	20	3	3				R 151,0 0	R 453,00
NB3- 50	V	50amp 3p 4,5ka curve	e a c h	20	2	1		1		R 151,0 0	R 151,00
NB3- 40	D D	40amp 3p,4,5ka curve din CB	e a c h	10	4	8				R 107,9 6	R 863,68
NB3- 32	U	32 amp 3p 4,5ka curve din MCB	e a c h	20	0	0				R 141,0 0	R -
NB3- 25	R	C curve circuit breakers 25A 3P	e a c h	30	14	14				R 141,0 0	R 1 974,00
NB3- 20	JJ	20 AMP 4,5KA curve din MCB	e a c h	20	0	0				R 141,0 0	R -
NB1-6	A5	6Amp 1p 4,5ka curcuit breaker	e a c h	20	16	16				R 36,00	R 576,00
GW92 168	H H	3P 16a breaker	e a c h	10	0	0				R 420,0 0	R -
NB1- 16	H H	16A 1P 4,5ka c ciurve din mcb	e a c h	20	4	5				R 36,00	R 180,00
NB1- 20	D	20 Amp 1p 4,5ka curve din mcb	e a c h	20	8	9				R 36,00	R 324,00
T25x25	2B	Grey slotted trunking 25wx25H	e a c h	10	4	4				R 35,20	R 140,80
T60x60	2B	Grey slotted trunking 60wx60H	e a	10	6	6				R 99,00	R 594,00

			ch							
T50RB LACK	2K	Cable tie blk 198x4,7mm	pack	10	3	3			R 70,40	R 211,20
TE151 2BK	II	Insul bootlace black duo/crimp 1,5mm	pack	10	100	10 0			R 0,54	R 54,00
T50LB LACK	2K	Cable tie black 395x4,7mm	pack	10	4	4			R 135,8 0	R 543,20
T18R WHITE	2K	Cable tie wht 104x2,5mm	pack	10	4	4			R 24,06	R 96,24
ZMEM/ 5	A2 3	Base for E relays IP20	each	10 0	54	54			R 52,00	R 2 808,00
MOD3 RM		MOD3RM	each	0	0	0	No		R -	R -
ZB4BZ 105		Bezel+1NC+1NO Contact Block	each	0	0	0	No		R -	R -
T30 Energi se		Delay timer - T30- electro - 230V/60 seconds	each	0	0	0	No		R -	R -
T2D		Delay timer - T2D- electro - 230VAC/400 DC 60 seconds	each	0	0	0	No		R -	R -
8LM2T ZL230		Diode Lamp - LM2T2L230 - Lovato - x2 230 VAC x1	each	0	0	0	No		R -	R -
BE-96		Direct AC Ammeter - BE - 96 - BEW - 96mm 60A	each	0	0	0	No		R -	R -
M266		Duct Sealer - M266- pekay - AK1 30-90	each	0	0	0	No		R -	R -
CS151 0		Duro flexible plain - 150 - advantage air - silver 10m	each	0	0	0	No		R -	R -
CS201 0		Duro flexible plain - 200- advantage air - silver 10m	each	0	0	0	No		R -	R -

CS256		Duro flexible plain - 250 - advantage air - 1200x600mm	each	0	0	0	No		R -	R -
D4/N 230VAC	W	4PDT 5A miniature relay	each	50	29	29			R 89,20	R 2 586,80
CS3010		Duro flexible plain - 300 - advantage act - silver core lom	each	0	0	0	No		R -	R -
LV429338		Extended Std Rotary Handle	each	0	0	0	No		R -	R -
EZ9F53363	E	Schneider Easy9 MCB 3P 63A 3KA 400V	each	20	0	0			R 128,59	R -
EZ9F53116	E	Schneider Easy9 MCB 1P 16A	each	20	0	0			R 38,29	R -
EZ9F53350	E	Schneider Easy9 MCB 50A 3KA 400V	each	20	0	0			R 128,59	R -
EZ9F53106	E	Schneider Easy9 MCB 1P 6A 3KA 230V	each	20	0	0			R 38,29	R -
EB4x2		Extention Box Steel 4x2 open	each	0	0	0	No		R -	R -
LPXC01		LATCH.M/Room Head-Twist Rel/LPX C01	each	0	0	0	No		R -	R -
XALK178		Estop station 40mm twist/rel	each	0	0	0	No		R -	R -
F1382		Egg crates - F1382 - advantage air - 1200x600mm	each	0	0	0	No		R -	R -
MIS55024-00-10		Fans - MIS55024-00-10- Kruger -V/Hz/PH 220 -240/50/1	each	0	0	0	No		R -	R -
W123BL		4,0 blue silicone wire	met	100					R 1	R -

			er s						086,0 0	
W101 R	SS	1,5mm red gp wire 100m	m et er s	20 0	0	0			R 331,0 0	R -
W101 BL	SS	1,5mm blue gp wire 100m	m et er s	20 0	100	10 0			R 331,0 0	R 33 100,00
W101 WH	SS	1,5mm white gp wire 100m	m et er s	20 0	0	0			R 331,0 0	R -
F2/100 8		Fibreglass Resini - F2/1008 - Luxor - 5.olt	e a c h	0	0	0	No		R -	R -
W124 BL	N N	6,0 blue silicone wire	m et er s	10 0	68	68			R 1 411,8 0	R 96 002,40
GAF		Filter - GAF - Filter mark - air dust arrester	e a c h	0	0	0	No		R 450,0 0	R -
600591 953540	B6	Welding rods afrox 3,15mm 5k	b o x	1	1	1			R 320,0 0	R 320,00
W123 R	LL	4,0 red silicone wire	m et er s	10 0	100	10 0			R 1 086,0 0	R 108 600,00
W123 BL	LL	4,0 bluesilicone cable	m et er s	10 0	90	90			R 1 086,0 0	R 97 740,00
W503 BR	TT	1,0mm brown flexible wire 100m	m et er s	10 0	0	0			R 212,0 0	R -
W105 - R	PP	10mm red gp wire /100m	m et er s	10 0	85	85			R 1 695,0 0	R 144 075,00
W103 BL	Q Q	4mm blue gp wire /100m	m et er s	10 0	0	0			R 805,0 0	R -
W503 BL	TT	1,0mm blue flexible wire/100m	m et er s	10 0	100	10 0			R 212,0 0	R 21 200,00

SLI 4,0 red	LL	4,0 red silicone cable	m et er s	10 0	100	10 0				R 1 086,0 0	R 108 600,00
W124 R	N N	6,0 red silicone cable 100m	m et er s	10 0	58	58				R 1 411,8 0	R 81 884,40
W124 WH	N N	6,0mm white silicone cable 100m	m et er s	10 0	68	68				R 1 411,8 0	R 96 002,40
W124 BL	N N	6,0 blue silicone wire	m et er s	10 0	68	68				R 1 411,8 0	R 96 002,40
W123 BL	LL	4,0 blue silicone cable	m et er s	10 0	100	10 0				R 1 086,0 0	R 108 600,00
W503 WH	TT	1,0mm white flexible wire/100m	m et er s	10 0	100	10 0				R 212,0 0	R 21 200,00
W102 BI	M M	2,5mm blue gp wire /100m	m et er s	10 0	100	10 0				R 516,0 0	R 51 600,00
W102 WH	M M	2,5mm white gp wire /100m	m et er s	10 0	100	10 0				R 516,0 0	R 51 600,00
W503 R	TT	1,0mm red flexible wire/100m	m et er s	10 0	0	0				R 212,0 0	R -
W102 R	M M	2,5mm red gp wire /100m	m et er s	10 0	95	95				R 516,0 0	R 49 020,00
W103 WH	Q Q	4mm white GP wire /100m	m et er s	10 0	100	10 0					R -
W103 R	Q Q	4mm red gp wire /100m	m et er s	10 0	100	10 0				R 805,0 0	R 80 500,00
W105 WH	PP	10mm white gp wire/100m	m et er s	10 0	85	85				R 1 695,0 0	R 144 075,00
W105 BL	PP	10mm blue gp wire/100m	m et er s	10 0	0	0				R 1	R -

			er s						695,00	
W104 WH	O O	6mm white gp wire /100m	m et er s	10 0	89	89			R 1 225,00	R 109 025,00
W104 R	O O	6mm red gp wire /100m	m et er s	10 0	89	89			R 1 225,00	R 109 025,00
W104 BL	O O	6mm blue gp wire /100m	m et er s	10 0	83	83			R 1 225,00	R 101 675,00
W503 BK	TT	1,0mm black flexible wire 100m	m et er s	10 0	100	10 0			R 212,00	R 21 200,00
W503 GR	TT	1,0mm grey flexible wire 100m	m et er s	10 0	30	30			R 212,00	R 6 360,00
W124 R	N N	6,0 red silicone cable	m et er s	10 0	100	10 0			R 1 411,80	R 141 180,00
W124 WH	N N	6,0 white silicone cable	m et er s	10 0	100	10 0			R 1 411,80	R 141 180,00
023Z1 404		Filter drier type C -165 Danfoss - HFC/HCFC/CFC	e a c h	0	0	0	No		R -	R -
FLEX 6MM		Flex 6mm red wire cable	e a c h	0	1	1	No		R 1 040,60	R 1 040,60
F06	II	Non ins ferrules 6mm	p a c k	10	94	94			R 111,00	R 10 434,00
F10	II	Non ins ferrules 10mm	p a c k	10	0	10 0			R 179,00	R 17 900,00
FLEX 4MM		Flex 4mm red wire cable	e a c h	0	1	1	No		R 703,56	R 703,56
2A		Fuse - 2A - Electro- mechanica -250V	e a c h	0	0	0	No		R -	R -
20A		Fuse - 20A - Electro - mechanica - 250V	e a	0	0	0	No		R -	R -

			c h							
8A		Fuse-8A - Electro - mechanica - 5x20mm	e a c h	0	0	0	No		R -	R -
15A		Fuse -15A -Electro - mechanica - 250V	e a c h	0	0	0	No		R -	R -
IEC/EN 60269		Fuse GL - IEC/EN 60269 - elf electric - 20A 500V	e a c h	0	0	0	No		R -	R -
IEC/EN 60269		Fuse GL - IEC/EN 60269 - elf electric - 10A 500V	e a c h	0	0	0	No		R -	R -
GGR0 410		R410a Dipossacan 11.3 kg	e a c h	0	0	0	No		R -	R -
10MM		Gauge cocks BSP	e a c h	0	0	0	No		R -	R -
L18220		L18W20 Tube flow	e a c h	0	0	0	No		R -	R -
14WC DLE27		Globes - 14WCDL E27 - Phillips - 220-240V / 1pf /12	e a c h	0	0	0	No		R -	R -
E14wb c840c w		Lamp saver elec saver	e a c h	0	0	0	No		R -	R -
M2 EP		Grease Yates - M2 EP - Fuchs - 5kg	e a c h	0	0	0	No		R -	R -
HTP10 11		HI- FLOWCONDESATE PUMP 2LSUMP	e a c h	0	0	0	No		R -	R -
RFA60 01		INS 1/4"ID X 1/4" WALL 6-6	e a c h	0	0	0	No		R -	R -
RFA60 02		INS 3/8"ID X 1/4" WALL 6-10	e a c h	0	0	0	No		R -	R -

RFA6003		INS 1/2"ID X 1/4" WALL 6-12/13	each	0	0	0	No			R -	R -
GO00019		INS 5/8"ID X 1/4" WALL 6-15/16	each	0	0	0	No			R -	R -
KF101/150MM		KF101/150MM Cast	each	0	0	0	No			R -	R -
KF101/200MM		KF101/200MM Cast	each	0	0	0	No			R -	R -
K569/15		KS69/15 AUTOMATIC AIRVENT	each	0	0	0	No			R -	R -
C42 24 VAC		Relay 8 pin round 10A 2c/0	each	10	6	6				R 108,60	R 651,60
EML3603033	2H	22kw 4p 380-415/660V motor	each	1	0	0				R 30 814,00	R -
EML3303033	2H	18,5kw 2p 380v motor	each	1	0	0				R 10 124,00	R -
EML4203033	2H	45kw 4P 380-415 motor	each	2	2	2				R 16 372,95	R 32 745,90
EML3803033	2H	30kw 4P 380-415 motor	each	1	1	0				R 10 798,70	R -
E52/S 24 VDC	M	2PDT PCB relay 5A	each	50	17	20				R 55,20	R 1 104,00
E52/S 24VAC	M	2PDT PCB relay 5A	each	50	12	12				R 69,20	R 830,40
BUV	I	Base 11 pin (oval) IP20	each	20	2	2				R 59,00	R 118,00
E52 /5 230VAC	M	2PDT PCB relay 5A	each	50	27	27				R 84,90	R 2 292,30

			each							
ZMD4	A17	Base for relay type D4	each	30	30	30			R 49,30	R 1 479,00
ZHRT1 - ST/A230	A19	230vac star delta timer 0,1s-100Hr	each	20	14	14			R 705,00	R 9 870,00
ZRUV	I	Relay base 11 pin rectangle blk	each	10	2	2			R 44,00	R 88,00
C42 24VAC	M	Relay 8 pin round 10A 2c/0	each	50	10	10			R 108,60	R 1 086,00
C42 230VAC	M	Relay 8 pin round 10A 2c/0	each	50	4	4			R 86,00	R 344,00
24v 8 pin		8 PIN Relay Miniture	each	0	0	0	No		R 89,76	R -
4co7a 24vac		Plug in Relay 4Co7a 24Vac	each	0	10	10	No		R 69,50	R 695,00
4co7a 230vac		Plug in Relay 4co7a 230vac	each	0	10	10	NO		R 82,58	R 825,80
60.12.8 .230.00 40		8 PIN Relay 10A-250V	each	0	0	0	No		R 126,50	R -
402824 0000		8A 230V AC COIL	each	0	21	21	No		R 102,96	R 2 162,16
60.12/2 20VAC		8 PIN Relay 10A-220V	each	0	5	5	No		R 126,50	R 632,50
80MM		80MM MCU cable	each	0	4	4	No		R 515,90	R 2 063,60
MKEL2 230V	J	Pilot light grn 22mm+lamp 230v	each	10	0	0			R 44,00	R -

MKEL 1230V	J	Pilot light red 22mm+lamp 230v	e a c h	10	0	0				R 35,20	R -
MKEL3 230V	J	Pilot light yellow 22mm+Lamp 230V	e a c h	10	0	0				R 35,20	R -
MCU		MCU BACNET/IP-24V	e a c h	0	0	0	No			R 6 700,6 0	R -
LK10Y R	A9	Yellow and red handle for KU	e a c h	10	1	1				R 166,0 0	R 166,00
L200A D11	A9	200mm ALU shaft	e a c h	10	1	1				R 33,00	R 33,00
KU340 N	A9	40A 3p isolator	e a c h	10	1	1				R 230,0 0	R 230,00
RL25X 10/10	II	Non insul ring lug 25x10mm/10	e a c h	30	10	0		10		R 84,80	R -
CONT/ 0350/0 0960	2E	Power pack 36v	e a c h	10	0	0				R 646,0 0	R -
ACS-2	F	Size 2 pvc shroud	e a c h	8	6	6				R 5,30	R 31,80
ACG-2	F	Size 2 metal gland for armoured cable	e a c h	10	4	24				R 56,00	R 1 344,00
ACG-3	F	Size 3 metal gland for armoured cable	e a c h	10	2	2				R 75,50	R 151,00
CONT/ 0100/0 0250	2E	MLM wall controller	e a c h	10	0	0				R 728,0 0	R -
CABL/ 0050/0 0175	2E	Power pack cable	e a c h	20	0	0	No			R 563,0 0	R -
ICO 10A		Mini pcb relay 40.61 - SA DFI.SN - Finder - 1010A 250V	e a	0	0	0	No			R 60,50	R -

			ch							
GW92 110	R	1P 25A C 4,5/6KA breaker	each	10	0	0			R 70,00	R -
CG-1	O	Size 1 white pvc compression gland	each	50	30	30			R 2,90	R 87,00
ICO 16A		Mini pcb relay 40.51 - SA.DI.SN - Finder - 16A 250V	each	0	0	0	No		R 27,10	R -
8LP2T 1L224 -Red		Mono block pilot light - 8LP2T IL224 -Lorato - 230V/2.6W max Red	each	0	0	0	No		R 37,70	R -
8LP2T 1L224 -Green		Mono block pilot light - 8LP2T IL224 -Lorato - 230V/2.6W max Green	each	0	0	0	No		R 37,70	R -
DMFT		Multifunction range Timer - DMFT - electro - 10A 250 VAC.00 VAC	each	0	0	0	No		R 410,7 0	R -
A25CN -9001		A25CN-9001 Over Heat Stsrts,0-100 degre C	each	0	0	0	No		R 1 425,8 2	R -
C4/111 8		Rust Converter Supreme 5lt	each	0	0	0	No		R 682,0 0	R -
NITTO WHITE	Q	Nitto white insulation tape	each	10	0	0			R 14,91	R -
NITTO RED	Q	Nitto red insulation tape	each	10	0	0			R 14,91	R -
NITTO BLUE	Q	Nitto blue insulation tape	each	10	0	0			R 14,94	R -
NB02A Q1 - 2Pole		On/off type switch- NB02AQ1-Baco - 50Hz/60Hz 1th20A/AC -21A	each	0	0	0	No		R 152,4 2	R -
NB03A Q1 - 3Pole		On/off type switch- NB03AQ1-Baco - 50Hz/60Hz 1th20A/AC -21A	each	0	0	0	No		R 172,0 5	R -

LS0160	II	Lugs4x10	each	100	0	0				R 4,60	R -
LS0450	II	Lugs 50x10 copper	each	100	0	0				R 14,84	R -
LS0130	II	Lugs 4x5	each	100	0	0				R 1,68	R -
LCID65AP7		3P ELINK CONT 220V 65A	each	0	0	0	No			R 3400,00	R -
LAN02	K	Schneider TVS front contactor 2NC	each	10	1	1				R 100,99	R 100,99
LAEN20	K	Schneider TVS aux front contactor 2NO	each	10	1	1				R 100,99	R 100,99
LRE359	M	Schneider TVS thermal overload relay 48-65a	each	5	2	2				R 695,99	R 1 391,98
RFX3804		Overload RF382300-RFX3804- Lovato - U1690V UIMP6KV	each	0	0	0	No			R 360,50	R -
LRD365		THERMAL OVERLOAD	each	0	0	0	No			R -	R -
HTP1012		ASPEN MINI AQUA IN LINE CONDENSOR PUMP	each	0	0	0	No			R -	R -
ALED - Y 230VAC	J	Yellow LED pilot light hi brite 22mm	each	50	3	3				R 47,00	R 141,00
ALED - G 230VAC	J	Green pilot light hi brite 22mm	each	50	0	0				R 42,00	R -
ALED - R 230VAC	J	Red pilot light hi brite 22mm	each	50	5	5				R 43,00	R 215,00
LPC S370		3Pos.Spring Ret From L+R	ea	0	0	0	No			R 128,70	R -

			ch							
Li-XB7-43		PILOT LIGHTS MCE GREEN-A	each	0	0	0	No		R 55,00	R -
8 LM2T1 L104		Pilot light head - 8 LM2T1L104 - Lovato - 1.2 3 3 Red	each	0	3		No		R 53,00	R -
HE207	2I	Orange panel IP55 1150x850x270	each	2	0	0			R 4 200,00	R -
AC 12AV		Pilot light -AC12V- Lovato -AC230V	each	0	0	0	No		R 47,00	R -
6871		PC board - 687111A000090R - Dun-ham Bush elec control board	each	0	0	0	No		R 209,00	R -
F80		F80 Fenaflex Nat Rubber Tyre	each	0	0	0	No		R 186,02	R -
ZB4BD 3		Sel.SW.HD.3POS.STA RYP	each	0	0	0	No		R 222,70	R -
IP65 6MM		Square key lock IP65 25MM	each	0	0	0	No		R 31,79	R -
110mm ² /S(cst)		Speed Grease- 110mm ² /S(sct) - BMG - 25 to 180 C/260 C	each	0	0	0	No		R 35,00	R -
FSU/4/ 80W		Starter FSU/4/80W	each	0	0	0	No		R 2,75	R -
P1/T26 11		Stoep paint green - P1/12611 - Plascon - 5lt	each	0	0	0	No		R 486,40	R -
LMTK-3		BO SELCTOR SWITCH ON/OFF AUTO	each	0	0	0	No		R 189,48	R -
DS-405	A2 7	CT 200m ring 40:5	each	10	0	0			R 132,00	R -

1way 4x2/24 71		Switch 1 Lever 2 way 4x2	e a c h	0	0	0	No			R 30,01	R -
GW44 209	A2 5	Enclosure plain sides 300x220x120IP56	e a c h	10	0	0				R 580,0 0	R -
P1/126 31		Stoep paint light grey - P1/12631 - Plascon - 5lt	e a c h	0	0	0	No			R 499,4 7	R -
SWA1 6X4/F R	2C	PVC/SWA/16mm x4c	m e t e r s	10 0	40	40				R 125,0 0	R 5 000,00
SWA1 0x4/FR	2C	PVC/SWA/PVC 10mmx4c fr	m e t e r s	10 0	0	0				R 96,98	R -
6541	A4	Coverplate	e a c h	1	0	0				R 14,70	R -
QF3(2 6),80A	H H	Circuit breaker 80A 5KA 26mm	e a c h	1	0	0				R 464,0 0	R -
2460/6 891	A4	Switch isolator	e a c h	1	0	0				R 108,0 0	R -
003412 6	A9	Socomec 125A 3P isolater	e a c h	10	0	0				R 829,2 5	R -
SWA1 0x4CU/ FR 001	2C	PVC /SWA/PVC 10mmx4 core cable	m e t e r s	10 0	0	0				R 96,98	R -
SEA04 003006	C1	Angle cq 40x40x3mm	e a c h	10	10	10				R 131,9 5	R 1 319,50
SFB04 003006	C2	Flat bar cq 40x3mm 6mtr	e a c h	5	5	5				R 75,70	R 378,50
SHR02 012252 450	C3	HR sheet cq 2450x1225x2	e a c h	10	9	9				R 649,8 4	R 5 848,56
TTS03 803000 6	C4	Sq /Tube 38x38x3,0- 6m	e a	40	37	37				R 338,3 5	R 12 518,95

			ch							
SCH07 603800 6	C5	Channel cq 5,7kg 76x386m	each	1	0	0			R 500,5 7	R -
VG621 0JC IDN 20		Surf/Din socket black - ES11 - Ersce -10A 300VAC/12A 150 VAC	each	0	0	0	No		R 26,47	R -
SQ96S P 40/5A	A2 6	Scale plate	each	10	0	0			R 17,00	R -
SQ96- 40AD	A2 9	Ammeter 40ac direct connected	each	10	1	1			R 266,0 0	R 266,00
SQ96- 5	A2 5	Ammeter AC ct driven w/o scale	each	10	3	3			R 243,0 0	R 729,00
SURF 2,5X2 WHT	R R	Coil surfix 2,5mmx2c white 10m	meter s	10 0	10	10			R 17,38	R 173,80
SURF2 ,5x2W HITE	R R	Coil surfix 2,5mmx2c white 100m	meter s	10 0	53	53			R 1 466,1 6	R 77 706,48
SFI 4000 vac		P/Filer Relays	each	0	0	0	No		R 235,9 5	R -
017024 G368		VLT HVAC DRIVE 45KW	each	2	0	0			R 52 142,4 0	R -
017006 H358		VLT HVAC drive	each	5	1				R 74 345,0 4	R -
VG621 0JC IDN 15		Two way valve - VG6210 JC/DN20 - DN20 pin 16	each	0	0	0	No		R 2 908,7 8	R -
R/ST- 12	P	Push button STN e- stop (twist to release)	each	10	1	1			R 222,0 0	R 222,00
RSA00 11		Two way valve - VG6210 JC/DN20 - DN15 pin 16	each	0	1	1	No		R 2 908,7 8	R 2 908,78

PN16, DN32, Kvs,16		Two way valve - VG7401PT PN 16,DN32,Kvs.16	e a c h	0	0	0	No		R 4 279,2 2	R -
RB944 -14F	W	230VAC 5A 14 pin mini relay 4 c/o	e a c h	10	9	9			R 48,00	R 432,00
RB2- BZ103	N	2 N/O contac block + base	e a c h	10	3	3			R 81,00	R 243,00
RB2- BD2	N	2 post maint short sel sw head	e a c h	20	18	18			R 121,0 0	R 2 178,00
RB750 -08R	I	8 pin relay base rectangle type blue	e a c h	10 0	50	50			R 45,00	R 2 250,00
RM/ST -12	P	D cast pushbutton STN E-stop (latch)	e a c h	10	5	6			R 518,0 0	R 3 108,00
R5504- 024VA CL	W	24VAC 5A 14pin mini relay +LED	e a c h	30	28	28			R 74,00	R 2 072,00
R5504- 024VD CL	W	24VDC 14 pin mini relay + LED	e a c h	30	27	27			R 74,00	R 1 998,00
RSA00 13		Tube CU SD 1/4" 6.35mm 15.24M	e a c h	0	0	0	No		R 403,7 0	R -
RSA00 14		Tube CU SD 3/8" 9.53mm 15.24M	e a c h	0	0	0	No		R 616,0 0	R -
RSA00 15		Tube CU SD 1/2" 12.7mm 15.24M	e a c h	0	0	0	No		R 995,5 0	R -
TC1- D1810 U	Z	7,5kw 400v 18A 3P contactor 1No 240VAC	e a c h	3	3	3			R 352,0 0	R 1 056,00
TC1- D2510 U	BB	11kw 400v 25a 3p contactor 1NO 240VAC	e a c h	7	4	5			R 514,0 0	R 2 570,00
TC1- D1210 U	C C	5,5kw 400v 12a contactor 1No 240VAC	e a	20	5	5			R 229,0 0	R 1 145,00

			ch							
TC1-D0910 U	FF	4kw 400v 9A 3P contactor 1NO 240VAC	each	20	13	13			R 219,00	R 2 847,00
TA1-DN11	K	Top mount aux 1n/0+1n/c	each	20	7	7			R 76,00	R 532,00
TA1-DN22	K	Top mount aux 2n/+2n/c	each	20	11	11			R 133,00	R 1 463,00
TC1-D3210 U	EE	18,5kw 400v 32A 3p contactor 1no 240vac	each	20	0	0			R 725,00	R -
TC1-D40U	G G	18,5kw 400v 3p contactor 1no+1nc	each	20	6	6			R 1 068,00	R 6 408,00
TC1-D50 U	AA	22kw 400v 50A 3p contactor 1no+1nc	each	20	4	4			R 1 238,00	R 4 952,00
TR2-D3235 5	A2 8	28-36A thermal overload relay	each	10	10	10			R 710,00	R 7 100,00
TR2-D6535 7	A7	46-65A thermal overload	each	20	7	7			R 776,00	R 5 432,00
TR2-D6535 9	A8	48-65A thermal overload relay	each	10	7	7			R 1 055,00	R 7 385,00
TR2-D2533 2	M	17-25A thermal overload relay	each	10	1	1			R 471,00	R 471,00
TS-6370D -C13	2F	Sensor 0-10V to 40d 290	each	10	0	0			R 1 216,08	R -
RFA60 00		Tube CU SD 5/8" 15.88mm 15.24M	each	0					R 1 216,08	R -
100/0/5 00		Multigrade Lubricant Oil	each	0	1	1	No		R 1 201,20	R 1 201,20

20MM FLXTR SAD	O	PVC 20mm strap saddle	e a c h	30	0	0				R 0,55	R -
20MM COUP LING	O	PVC 20mm coupling	e a c h	30	0	0				R 0,22	R -
20MM ALEAD T	O	PVC 20mm male adaptor	e a c h	20	0	0				R 0,35	R -
20MM SABS	2A	PVC 20mm sabs conduit 4m	e a c h	20	6	6				R 7,96	R 47,76
ML743 0E100 5		vaccum pump oil	e a c h	0	0	0	No			R 1 716,0 0	R -
100332 22		SDPI 30s 230vac star/delta timer	e a c h	5	0	0	No			R 224,0 0	R -
DP1 30s 230VA C	X	Timer delay on 1c/0	e a c h	10	0	0				R 190,0 0	R -
SDP1 30s 230VA C	Y	Star /delta timer 30s	e a c h	30	3	3				R 220,0 0	R 660,00
SLI2,5 blue	M M	Silicone wire 2,5 blue	e a c h	10 0	90	90					R -
SLI 2,5 white	M M	Silicone wire 2,5mm white	m e t e r s	10 0	100	10 0				R 9,65	R 965,00
SLI 4,0 red	LL	Silicone wire 4,0 red	m e t e r s	10 0	100	10 0				R 15,44	R 1 544,00
SLI 2,5 Red	M M	Silicone wire 2,5 red	m e t e r s	10 0	100	10 0				R 9,65	R 965,00
100/0/5 00		Valve -ML7430E1005 - Honewell - 24V 50Hz 4VA 1p54	e a c h	0	0	0				R 9,65	R -
SLOT8 0x60	2B	Trunking slotted W80xh60 narrow	e a	10	2	2				R 99,00	R 198,00

			c h							
SLOT6 0x40	2B	Trunking slotted W60xH40 narrow	e a c h	10	2	2			R 70,88	R 141,76
SLOT4 0x40	2B	Trunking slotted W40xH40 narrow	e a c h	10	2	2			R 66,04	R 132,08
WALL4 x2	A3	Wall box 4x2 galvanized	e a c h	10	8	8			R 3,42	R 27,36
VB135 3	A6	16A 3P 1-0-2 door mount c/o switch	e a c h	20	7	7			R 193,0 0	R 1 351,00
VB10N X1080 f	2D	SPZ 1080 fenner wedge belt	e a c h	20	10	10	No		R 26,12	R 261,20
VB10N X1250	2D	SPZ 1250 fenner wedge belt rex	e a c h	20	10	10	No		R 29,46	R 294,60
VB10N X1320 f	2D	SPZ 1320 f -pitch length	e a c h	20	10	10	No		R 29,79	R 297,90
VB10N X1340 F	2D	SPZ 1340 fenner wedge belt	e a c h	20	10	10	No		R 28,90	R 289,00
VB10N X1400	2D	SPZ 1400	e a c h	20	10	10	No		R 34,05	R 340,50
VB10N X1520	2D	SPZ 1520 fenner wedge belt	e a c h	20	10	10	No		R 37,11	R 371,10
VB10N X1600	2D	SPZ 1600 fenner wedge belt	e a c h	20	20	20			R 39,07	R 781,40
VB13N X1700	2D	SPA 1700 fenner wedge belt	e a c h	20	10	10	No		R 41,68	R 416,80
VB13N X1800 F	2D	SPA 1800- Fenner - wedge belt	e a c h	20	10	0	No		R 49,83	R -

VB10N X1900 F	2D	SPZ 1900 fenner wedge belt	e a c h	20	20	20				R 45,92	R 918,40
VB10N X1900 F	2D	SPZ 1900 fenner wedge belt	e a c h	20	10	10	No			R 51,82	R 518,20
VB13N X2300 f	2D	SPA 2300 fenner w/belts	e a c h	20	10	0	No			R 62,83	R -
VB13N X1600	2D	SPA 1600 fenner wedge belt	e a c h	20	10	10	No			R 43,93	R 439,30
VB13N X2120 F	2D	SPA 2120 fenner wedge belt	e a c h	20	10	10	No			R 57,80	R 578,00
VB10N X1700	2D	SPZ 1700 fenner wedge belt	e a c h	20	20	20	No			R 37,20	R 744,00
VB10N X1800	2D	SPZ 1800 fenner wedge belt	e a c h	20	10	10	No			R 38,83	R 388,30
VB10N NX150 0	2D	SPZ 1700 fenner wedge belt	e a c h	20	10	10				R 36,50	R 365,00
VB13N X2240	2D	SPA 2240 fenner wedge belt	e a c h	20	10	10	No			R 60,97	R 609,70
13X16 25		V-Belt - 1625- Fenner - Heat Resistant	e a c h	0	0	0	No			R 44,00	R -
13X16 50		V-Belt - 1650- Fenner - Heat Resistant	e a c h	0	0	0	No			R 40,00	R -
13X26 67		V-Belt - 2667- Fenner - Heat Resistant	e a c h	0	0	0	No			R 51,72	R -
SPA85 0		V-belt - SPA 850 - Fenner - Heat Resistant	e a c h	0	0	0	No			R 58,00	R -
SPA10 00		V-belt - SPA 1000 - Fenner - Heat Resistant	e a	0	0	0	No			R 36,04	R -

			ch							
SPA1120		V-belt - SPA 1120 - Fenner - Heat Resistant	each	0	0	0	No		R 39,52	R -
SPA1250		V-belt - SPA 1250 - Fenner - Heat Resistant	each	0	0	0	No		R 38,81	R -
SPA1200		V-belt - SPA 1200 - Fenner - Heat Resistant	each	0	0	0	No		R 42,92	R -
VB10N X1600		SPZ 1600 fenner wedge belt	each	20	10	0	No		R 39,07	R -
SPA1800		V-belt - SPA 1800 - Fenner - Heat Resistant	each	0	0	0	No		R -	R -
VB13N X1900 F		SPA 1900 fenner wedge belt	each	20	10	0	No		R 51,82	R -
SPA200		V-belt - SPA 2000 - Fenner - Heat Resistant	each	0	0	0	No		R -	R -
VB13N X2120		SPA 2120 fenner wedge belt	each	0	0	0	No		R 67,61	R -
SPA2240		SPA 2240 fenner wedge belt	each	0	0	0	No		R -	R -
SPA2500		V-belt - SPA 2500 - Fenner - Heat Resistant	each	10	10	0	No		R 62,83	R -
SPA2650		V-belt - SPA 2650 - Fenner - Heat Resistant	each	0	0	0	No		R -	R -
SPA2800		V-belt - SPA 2800 - Fenner - Heat Resistant	each	0	0	0	No		R -	R -
SPA2840		V-belt - SPA 2840 - Fenner - Heat Resistant	each	0	0	0	No		R -	R -

B30/17 X770	V- Belt - B30/17x770 - Fenner - Heat Resistant	e a c h	0	0	0	No			R -	R -
B30/17 X900	V- Belt - B30/17x900 - Fenner - Heat Resistant	e a c h	0	0	0	No			R -	R -
B30/17 X925	V- Belt - B30/17x925 - Fenner - Heat Resistant	e a c h	0	0	0	No			R -	R -
B30/17 X965	V- Belt - B30/17x965 - Fenner - Heat Resistant	e a c h	0	0	0	No			R -	R -
B44/17 X1120	V- Belt - B44/17x1120 - Fenner - Heat Resistant	e a c h	0	0	0	No			R -	R -
B62/17 X1575	V - Belt -B62/17x1575 - Fenner - Heat Resistant	e a c h	0	0	0	No			R -	R -
B30/17 X1215	V- Belt - B30/17x1215 - Fenner - Heat Resistant	e a c h	0	0	0	No			R -	R -
B76/17 X1930	V - Belt _ B76/17x1930 - Fenner - Heat Resistant	e a c h	0	0	0	No			R -	R -
B55/17 x1400	V - Belt - B55/17x1400 - Fenner - Heat - Resistant	e a c h	0	0	0	No			R -	R -
B56/17 X1430	V - Belt _ B56/17x1430 - Fenner - Heat Resistant	e a c h	0	0	0	No			R -	R -
B57/17 X1450	V- Belt - B57/17x1450 - Fenner - Heat Resistant	e a c h	0	0	0	No			R -	R -
B83/17 X2100	V- Belt - B83/17x2100 - Fenner - Heat Resistant	e a c h	20	10	0	No			R 37,20	R -
B85/17 X2160	V- Belt - B85/17x2160 - Fenner - Heat Resistant	e a c h	0	0	0	No			R -	R -
B80/17 x2042	v- Belt - B80/17x2042 - Fenner - Heat Resistance	e a	0	0	0	No			R -	R -

			ch								
B92/17 X2210		V- Belt - B92/17x2210 - Fenner - Heat Resistant	each	0	0	0	No			R -	R -
B86/17 X2200		V- Belt - B86/17x2200 - Fenner - Heat Resistant	each	0	0	0	No			R -	R -
B94/17 X2337		V- Belt - B94/17x2337 - Fenner - Heat Resistant	each	0	0	0	No			R -	R -
B56/17 X2438		V-Belt - B56/17x2438 - Fenner - Heat Resistant	each	0	0	0	No			R -	R -
B93/17 2370		V - Belt - B93/17x2370 - Fenner - Heat Resistant	each	0	0	0	No			R -	R -
B97/17 X2470		V- Belt - B97/17x2470 - Fenner - Heat Resistant	each	0	0	0	No			R -	R -
B98/17 X2500		V- Belt - B98/17x2500 - Fenner - Heat Resistant	each	0	0	0	No			R -	R -
B100/1 7x2540		V - Belt - B100/17x2540 -Fenner Heat Resistant	each	0	0	0	0			R -	R -
B99/17 X2515		V- Belt - B99/17x2515 - Fenner - Heat Resistant	each	0	0	0	No			R -	R -
B105/1 7X267 0		V- Belt - B105/17x2670 - Fenner - Heat Resistant	each	0	0	0	No			R -	R -
B82/17 X2083		v - Belt - B82/17x2083 - Fenner - Heat Resistant	each	0	0	0	No			R -	R -
B81/17 X2060		v - Belt - B81/17x2060 - Fenner - Heat Resistant	each	0	0	0	No			R -	R -
B108/1 7X275 0		V- Belt - B108/17x2750 - Fenner - Heat Resistant	each	0	0	0	No			R -	R -

FC-102-HAVAC		FC-HVAC-4.1KW-380-480 VOITIP 20	each	0	0						R-
SPZ 850		V-Belt - SPZ 850-Fenner - Heat and Oil Resistant	each	0	0	0	No			R-	R-
B118/17X3000		V- Belt - B118/17x3000 - Fenner - Heat Resistant	each	0	0	0	No			R-	R-
SPB1340		V- Belt - SPB 1340-Fenner - Heat Resistant	each	0	0	0	No			R-	R-
SPB2400		V-Belt - SPB 2400 - Fenner - Heat Resistant	each	0	0	0	No			R-	R-
VB10N X1800		SPZ 1800 fenner wedge belt	each	0	0	0	No			R-	R-
C22X3810		V- Belt - C22x3810 - Fenner - Heat Resistant	each	20	10	0	No			R 38,83	R-
C22X2450		V-Belt - C22x2450 - Fenner - Heat Resistant	each	0	0	0	No			R-	R-
TP41 - 5TR		Yellow paint -TP41-5TR - Plascon -5lt	each	0	0	0	No			R-	R-
			each	0	0	0	No			R 145,25	R-
										Total	R 2 881 002,04

Maintenance of Roof ventilators and HVAC Mechanical Systems Spares List



ANNEX N

ACSA maintenance procedure for Roof ventilators - D080 025M

- Available upon request from the ACSA service manager

ACSA maintenance procedure for Roof ventilators and HVAC Mechanical Systems - D080 025M

- Available upon request from the ACSA service manager



ANNEX O

Roof ventilators and HVAC Mechanical Systems – standard operating procedure

N/A



ANNEX P

Maintenance of Roof ventilators and HVAC Mechanical Systems – Electrical lockout procedure

Available upon Request from the ACSA service manager



ANNEX Q

O.R. Tambo International Airport – operating instruction for Roof ventilators and HVAC Mechanical Systems

N/A



ANNEX R

Roof ventilators and HVAC Mechanical Systems - Fire Emergency procedure

N/A



ANNEX S

ACSA IMC procedure for call out and work orders

Available upon Request from the ACSA service manager

**ANNEX T**Internal and external factors

Below is a list of internal and external factors which may affect equipment availability and are beyond the contractor's control:

	Type	Comment
External resources	Utilities •Water •Electricity •Gas •IT Support and other interfaces outside the contractor battery limit	-No impact to reliability/Maintainability. -It Impact on availability from operations view
External causes	•Outside Operating conditions/parameters •Operator fault/incorrect operation, consider shifting the risk to the Service provider by giving him responsibility to support Operations/Operators •Damage by others(users and Third parties) i.e. Elevator doors •Incorrect use •Foreign material in system	-No impact to reliability/Maintainability. -Impact on availability from operations view This are some of the occurrences that may not be considered the Normal Operating conditions
Other	•Lack of information/Drawings •Lack of access due to no fault of the contractor after they have requested access timeously •Equipment's under Projects •Other factors that can be proven that was beyond the contractor's fault	
Spares	Availability of spares (if the spares are not under the control of the Service provider to the limit of the budget)	-Affect Maintainability



	Typically: It is the responsibility of the Client to ensure adequate administration and re-order spares timely, It is the responsibility of the service provider to ensure that the stores administration is done and minimum stock levels are adhered to, the request to buy spare are replenished are done on time intime	No impact on service provider. The Risk is not sitting with a single owner
--	--	--

**ANNEX U**

ACSA Mechanical Standardised Minimum: legal requirements and minimum competency requirements

Each site to maintenance technician and assistant. Filter cleaner and assistant for all sites.

Site Supervisor	• SAQA Accredited Trade test Electrician/Control and Instrumentation • OHS Training certificate	• Min 3 years experience post trade test qualification • 2 years supervisory Experience • Min 2 years OHS experience	• Registration with the Department of Labour as an Electrical Contractor
Control Technicians	SAQA Accredited Control and or Instrumentation Trade test certificate OR N5 In controls and or Instrumentation	Min 3 years experience post trade test qualification and 2 years must be on the maintenance of Control panels, PLCs, SCADA, VSDs, sensors, Controllers and solid understanding of electronic communication protocols	
Lead Electrician	• SAQA Accredited Trade test (Electrician) • Master Installation Electrician licence		
Electricians	• SAQA Accredited Trade test (Electrician)		
assistants	Electrical N2		
Independet assurance Control Engineer (For adhoc Quartely system integrity assurance)	• BSC/BENG Electronic Engineering/Mechatronics + PrEng registration; or • BTECH Electronics Engineering/Mechatronics + PrTech		



ANNEX V

ACSA Inventory procedure

Available upon Request from the ACSA service manager



ANNEX W

Current Guarantee and Warrantee

N/A