
SIGNAGE LEGEND

FIRE EQUIPMENT SIGNS	Location of Firefighting Equipment	Fire Extinguisher	Fire Hose Reel	Fire Hydrant
WALL MOUNTED: WALL MOUNTED PHOTOLUMINESCENCE FIRE SAFETY SIGNS TO COMPLY WITH SABS 1186/T.4.29, SECURED TO WALL.	 FB 1	 FB 2	 FB 3	 FB 4
	Fire Alarm	Sprinkler Stop Valve	Fire Telephone	Fire Pump Connection
	 FB 5	 FB 6	 FB 7	 FB 8
	Location of Fire Blanket	Hand-held Emergency Alarm	Fire Trolley	Fire Exit Sign
	 FB 9	 FB 13	 FB 14	 FB 16
	No Smoking	No Cellphone	No Open Flame	No Entry
	 PV 1	 PV 27	 PV 2	 PV6
GENERAL INFOMATION SIGNS	General Direction	General Direction	Escape Route (Left Sign)	Escape Route (Right Sign)
CEILING MOUNTED: PHOTOLUMINESCENCE FIRE SAFETY SIGNS TO COMPLY WITH SABS 1186/T.4.29, SECURED TO CEILING, 2500MM AFFL TO UNDER SIDE OF SIGN, IN AN ANODIZED ALUMIMIUM SUSPENDABLE FRAME.	 GA 1	 GA 2	 GA 3	 GA 4
	Ladies Toilet	Unisex Toilet	Gents Toilet	Accessible by Wheelchair
	 GA 5	 GA 6	 GA 2	 GA 22
	Refuge Chamber	First-Aid Equipment	Manned First-Aid Station	Drinking Water
	 GA 12	 GA 1	 GA 5	 GA 6
	Emergency Exit	Emergency Assembly Point		
	 GA 33	 GA 33		

Class of Occupancy	Number of portable fire extinguishers required per m²:	Number of Hose Reels required per m²:	Number of Hydrants required per m²:
J2	1/100m²	1/500m²	1/1000m²
	Portable Fire Extinguishers Supplied :	**Number of Hose Reels Supplied :**	**Number of Hydrants Supplied :**
	10 x 9kg	4	1



2 FIRE PLAN - FIRST FLOOR
1 : 150

1 FIRE PLAN - GROUND FLOOR
1 : 150

Do not scale off drawing - ASK THE ENGINEER IF UNCERTAIN!
Any discrepancies between any drawings must be clarified before work is continued on site.

APPROVAL BY COMMITTEE

Signed on this date: _____

Name: _____ Signature: _____

Name: _____ Signature: _____

Name: _____ Signature: _____

Name: _____ Signature: _____

FOR APPROVAL PURPOSES ONLY

READ THIS DRAWING IN CONJUCTION WITH

Drawing Number	Drawing Description

AMENDMENTS

Rev.	Date	Description	Initials

Vivian Smit

P.O.Box 677, Vryheid, 3100.
Cell Nr: 0784355514

Registered Professional (SACAP) Pr.Arch.T No. T1406
Registered Engineering Technician Reg Ing Tech - No 9940034

Engineering Council of South Africa
E-mail - viviansmit@lantic.net

Vivian Smit Drawings

Occupancy : **J2**
PLAN No : **04-09**
Sheet : **13 of 24**
11 May 2026

Approved by Architect: Signature:
Name:
Designation:
SACAP/ ECSA Reg :
Date: 2026/05/13

Project Funder/ Client:
KWAZULU-NATAL PROVINCE
PUBLIC WORKS & INFRASTRUCTURE
REPUBLIC OF SOUTH AFRICA
NKANDLA LOCAL MUNICIPALITY
UMLALASIPATALA
WASE NKANDLA

Project Implementing Agent:
public works
Department:
Public Works
PROVINCE OF KWAZULU-NATAL

Approved by Client:
Name: _____
Signature: _____ Date: _____

Project:

NKANDLA DISASTER MANAGEMENT CENTRE

Drawing description:

FIRE PLAN

Drawn: J vd Sandt	Checked: J.W JvR
Date:11/25/25	Date: 2026/05/13
Scale/s: As Shown	
Drawing number: 19-21-V-00-04-09	Rev.: 00